

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

County	Pratt	Fraction	1/4	Section number	21	Township number	T 28	Range number	S R 11
1. Location of well:		Distance and direction from nearest town or city: 35 / E			3. Owner of well: Wayne Dudley R2 Stafford, KS				
Street address of well location if in city: Cairo, KS					City, state, zip code:				
4. Locate with "X" in section below: <div style="text-align:center;">N 1 Mile W [Diagram] E S 1 Mile</div>					Sketch map:				
5. Type and color of material					From	To	6. Bore hole dia. 30 in. Completion date _____ Well depth 196 ft. 2-2-77		
								7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary	
Top Soil - Sandy clay Sand Clay Sand - Gravel clay Sand - Gravel					0	43	8. Use: Domestic ___ Public supply ___ Industry ___ <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other ___		
							9. Casing: Material Steel Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight ___ lbs./ft. Dia. 16 in. to 136 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 3/16		
					43	110	10. Screen: Manufacturer's name Doerr Type Steel Dia. 16" Slot/gauze 1/8" Length 60 Set between 136 ft. and 196 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 - 3/4"		
							11. Static water level: _____ mo./day/yr. 62 ft. below land surface Date 2-2-77		
					110	135	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. 102 ft. after 4 hrs. pumping 1250 g.p.m. Estimated maximum yield 1400 g.p.m.		
							13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date _____		
							14. Well head completion: Pitless adapter 12 Inches above grade		
							15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement ___ Bentonite ___ Concrete ___ Depth: From 0 ft. to 10 ft.		
							16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes ___ No ___		
							17. Pump: Not installed Manufacturer's name Goulds Model number 4125 HP 80 Volts _____ Length of drop pipe 150 ft. capacity 1000 g.p.m. Type: _____ Submersible <input checked="" type="checkbox"/> Turbine Jet Reciprocating Centrifugal Other		
(Use a second sheet if needed)									
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Water Well Ser. 186 Business name License No. Address R2 Great Bend, KS Signed Kelly Price Date 5-2-77 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5