


1. Location of well:		County PRATT	Fraction SW 1/4 NE 1/4 SE 1/4	Section number 5	Township number T 28	Range number S R 12 W E/W
2. Distance and direction from nearest town or city: 4E & 1S of Pratt			3. Owner of well: Biel Robbins R.R. or street: City, state, zip code: Pratt, Ks			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 18 in. Completion date 31 Dec 77 Well depth 160 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
Soil		0	2	9. Casing: Material STL Height: 0 above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
Clay, tan		2	4	Dia. 12 in. to 80 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .312		
Caliche, med. hard		4	17	10. Screen: Manufacturer's name Amfco Type <input type="checkbox"/> Dia. 12" Slot/gauze 1/8 Length 20' Set between 80 ft. and 100 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 1/2		
Clay, white and tan		17	27	11. Static water level: 74 ft. below land surface Date 31 Dec 77		
Sand, fine to med. silty		27	34	12. Pumping level below land surfaces: 82 ft. after 1 hrs. pumping 400 g.p.m. 84 ft. after 1 hrs. pumping 450 g.p.m. Estimated maximum yield 500 g.p.m.		
Sand, fine to coarse and med. to coarse gravel		34	80	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 31 Dec 77		
Sand, fine to coarse and fine to very coarse gravel		80	114	14. Well head completion: 12 inches above grade Pitless adapter <input type="checkbox"/>		
Clay, sandy tan		114	117	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Sand, fine to coarse and fine to coarse gravel		117	130	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type ADNE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Manufacturer's name Layne Not installed Model number <input type="checkbox"/> HP 20 Volts <input type="checkbox"/> Length of drop pipe 90 ft. capacity 400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks: 3'x3'x8" slab poured at surface		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump Svc. 325 Business name License No. Address 121 S. Taylor Pratt, Ks. Signed 7/78 Date Authorized representative		