

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction 1/4 cnw 1/4 ne 1/4	Section number 26	Township number T 28 S R 12W E/W	Range number
2. Distance and direction from nearest town or city: 3s 7 1/2 e			3. Owner of well: Damac Drilling Drlg, Inc.		
Street address of well location if in city: Pratt, Ks.			R.R. or street: Box 1164		
			City, state, zip code: Great Bend, Ks.		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. 8 in. Completion date 4-1-78		
			Well depth 152 ft.		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> Height: Above o 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 152 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. sch 40		
			10. Screen: Manufacturer's name Jetstream		
			Type pvc Dia. 5"		
			Slot/gauze 1/32" Length 40'		
			Set between 112 ft. and 152 ft.		
			Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"		
			11. Static water level: 59 ft. below land surface Date 4-1-78		
			12. Pumping level below land surfaces:		
			____ ft. after ____ hrs. pumping ____ g.p.m.		
			____ ft. after ____ hrs. pumping ____ g.p.m.		
			Estimated maximum yield 60 g.p.m.		
			13. Water sample submitted: ____ mo./day/yr.		
			Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion:		
			____ Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/>		
			With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/>		
			Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: oil		
			ft. 60 Direction n Type test		
			Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>		
			17. Pump: Not installed		
			Manufacturer's name Goulds		
			Model number utm HP 5 Volts 230		
			Length of drop pipe 126 ft. capacity 50 g.p.m.		
			Type:		
			<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine		
			<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating		
			<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:			
Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name R2, Great Bend, Ks. License No. 29 Address Great Bend, Ks. Signed Kelly Price Date 9-18-79 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5