

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

2813W 35NW 1/4 NE
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pratt	Township name Center	Fraction NW-NN-NE	Section number 35	Town number T-28-S	Range number R-13-W
Distance and direction from nearest town or city: 4.5 South 1 1/2 E Street address of well location if in city: Pratt Kansas				3 Owner of well: Nellie Lilly Est. Address: Pratt, Kansas		
Locate with "X" in section below:		Sketch map:		4 Well depth: 120 ft. Date of completion: 2-9-76 Well diameter: 8 3/4 in. 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____ 7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. Diam. 5 in. to 120 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
2 Type and color of material				From	To	8 Screen:
Top Soil				0	2	Manufacture: skess & Lowell
Black Clay				2	8	Type: RMP Dia. 5"
Clay LT. BROWN				8	35	Slot: 1/8 Length 20'
Sandy Clay				35	47	Set between 108 ft. and 120 ft.
Gravel				47	55	Fittings: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material: 4-3/8
Clay (LT. Br.)				55	75	9 Static water level:
Gravel				75	85	89 ft. below land surface Date: 2-9-76
Sandy Clay				85	104	10 Pumping level below land surfaces:
Gravel				104	118	89 ft. after 1 hrs. pumping 10 g.p.m.
Clay				118	120	_____ ft. after _____ hrs. pumping _____ g.p.m.
						Estimated maximum yield 15 g.p.m.
						11 Water sample submitted:
						<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
						12 Well head completion:
						<input type="checkbox"/> Pitless adapter 16 inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						<input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____
						Depth: From 4 ft. to 14 ft.
						14 Nearest source of possible contamination:
						ft. 75 Direction SW Type BARN
						Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump:
						<input type="checkbox"/> Not installed
						Manufacturer's name F+W
						Model number 7BA12 HP 3/4 Volts 220
						Length of drop pipe 105' capacity 12 g.p.m.
						Type:
						<input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation				17 Water well contractor's certification:		
Land Slopes To South Away From Well				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography:				Signed Carl Hayes Date 2-9-76		
<input type="checkbox"/> Hill				Business name 603 S. Maple Greensburg		
<input checked="" type="checkbox"/> Slope				Address 603 S. Maple Greensburg		
<input type="checkbox"/> Upland				License No. _____		
<input type="checkbox"/> Valley				Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5