


1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: Pratt		nw 1/4 se 1/4 sw 1/4	17	T 28 S	R 13w E/W
Distance and direction from nearest town or city? 2s 1 3/4w Pratt, Ks.			Street address of well if located within city?		
2 WATER WELL OWNER:		H-30 Drlg Inc			
RR#, St. Address, Box # :		200 N. Main			
City, State, ZIP Code :		Wichita, Ks. 67202			
3 DEPTH OF COMPLETED WELL		135 ft. Bore Hole Diameter 8 in. to 135 ft. and in. to			
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well			
1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)		2 Irrigation 4 Industrial 7 Lawn and garden only 10 Observation well			
Well's static water level 60 ft. below land surface measured on 6 month 27 day 78 year		Pump Test Data			
Est. Yield 70 gpm:		Well water was ft. after hours pumping gpm			
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped			
1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded		2 PVC 4 ABS 7 Fiberglass Threaded			
Blank casing dia 5 in. to 95 ft. Dia in. to ft. Dia in. to		Casing height above land surface 12 in. weight 2.8 lbs./ft. Wall thickness or gauge No sch 40			
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement			
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)		2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)			
Screen or Perforation Openings Are:		5 Gauzed wrapped 8 Saw cut 11 None (open hole)			
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes		2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)			
Screen-Perforation Dia 5 in. to 40 ft. Dia in. to ft. Dia in. to		Screen-Perforated Intervals: From 95 ft. to 135 ft. From ft. to ft. to			
Gravel Pack Intervals: From 10 ft. to 135 ft. From ft. to ft. to		5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other			
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. to		What is the nearest source of possible contamination:			
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well		2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well			
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)		Direction from well nw How many feet 65 ? Water Well Disinfected? Yes No X			
Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year Pump Installed? Yes No		If Yes: Pump Manufacturer's name Model No. HP Volts			
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.		Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other			
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 6 month 27 day 78 year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 186					
This Water Well Record was completed on 11 month 19 day 79 year under the business name of Kellys Waterwell Serv. by (signature) <i>Kelly Price</i>					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0 60 Top Soil-Clay			
		60 80 Sand-Gravel			
		80 90 Clay			
		90 135 Sand-Gravel			
ELEVATION: unk					
Depth(s) Groundwater Encountered 1. 60 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)					
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.					