


BREHER H1

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number
County: PRATT		NE 1/4 NE 1/4 SW 1/4	30	T 28 S	R 13 E
Distance and direction from nearest town or city? PRATT 4.5 2 1/2 W 1/2 N			Street address of well if located within city?		
2 WATER WELL OWNER: STERLING DRILLING CO. Rm #, St. Address, Box #: 129 City, State, ZIP Code: STERLING, KS 67579			Board of Agriculture, Division of Water Resources Application Number: T80-116		
3 DEPTH OF COMPLETED WELL: 120 ft. Bore Hole Diameter: 9 in. to 120 ft. and in. to ft.					
Well Water to be used as:		5 Public water supply		8 Air conditioning	
1 Domestic 3 Feedlot		6 Oil field water supply		11 Injection well	
2 Irrigation 4 Industrial		7 Lawn and garden only		12 Other (Specify below)	
Well's static water level: 80 ft. below land surface measured on		Set Mar month		1 day 1980 year	
Pump Test Data: NONE		Well water was		ft. after hours pumping	
Est. Yield gpm:		Well water was		ft. after hours pumping	
4 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		8 Concrete tile	
2 PVC		4 ABS		9 Other (specify below)	
Blank casing dia: 5 in. to 100 ft. Dia		7 Fiberglass		Casing Joints: Glued XX Clamped	
Casing height above land surface: 12 in. weight 287.3 lbs./ft. Wall thickness or gauge No. 265				Welded	
TYPE OF SCREEN OR PERFORATION MATERIAL:				Threaded	
1 Steel		3 Stainless steel		5 Fiberglass	
2 Brass		4 Galvanized steel		6 Concrete tile	
Screen or Perforation Openings Are: 1/8		5 Gauzed wrapped		8 Saw cut	
1 Continuous slot		3 Mill slot		9 Drilled holes	
2 Louvered shutter		4 Key punched		10 Other (specify)	
Screen-Perforation Dia: 5 in. to 120 ft. Dia				11 None (open hole)	
Screen-Perforated Intervals: From 100 ft. to 120 ft.					
Gravel Pack Intervals: From 90 ft. to 120 ft.					
5 GROUT MATERIAL:					
1 Neat cement		2 Cement grout		3 Bentonite	
Grouted Intervals: From 0 ft. to 10 ft.				4 Other	
What is the nearest source of possible contamination: NONE					
1 Septic tank		4 Cess pool		7 Sewage lagoon	
2 Sewer lines		5 Seepage pit		8 Feed yard	
3 Lateral lines		6 Pit privy		9 Livestock pens	
Direction from well		How many feet		Water Well Disinfected? Yes No	
Was a chemical/bacteriological sample submitted to Department? Yes No					
If Yes: Pump Manufacturer's name					
Model No. HP Volts					
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.					
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Mar month 1 day 1980 year					
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 389					
This Water Well Record was completed on Mar month 7 day 1980 year under the business name of MYERS WATER WELL SERVICE by (signature) R. A. Reiser					
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG	
		0 4 SOIL			
		4 35 DRY GRAVEL			
		35 40 CLAY			
		40 70 SANDY-FINE			
		70 100 CLAY			
		100 120 GRAVEL			
ELEVATION:					
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)					
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.					

OFFICE USE ONLY

T

R

R

FW

SEC.

NE 1/4 NE 1/4 SW 1/4