


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <u>Pratt</u>	Township name <u>Richland</u>	Fraction <u>NE 1/4 NE 1/4 NE 1/4</u>	Section number <u>2</u>	Town number <u>28</u>	Range number <u>14</u>
Distance and direction from nearest town or city: <u>4 West</u> Street address of well location if in city: <u>1/4 North Pratt</u>			3 Owner of well: <u>Elwood Lawrence</u> Address: <u>RFD 4 Pratt</u>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: <u>60</u> ft. Date of completion <u>3-23-75</u> Well diameter <u>10</u> in.
2 Type and color of material <u>No Log Made</u>			From To			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
						6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
						7 Casing: Material <u>RMP</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>6 1/2</u> Weight <u>200</u> lbs./ft. <u>60</u> <u>5</u> in. to <u>60</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No — in. to — ft. depth
						8 Screen: Manufacturer <u>Jess + Lowell</u> Type <u>RMP</u> Dia. <u>5 1/2</u> Slot/gauze <u>7/16</u> Length <u>10'</u> Set between <u>50</u> ft. and <u>60</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>4/16 - 3/8</u>
						9 Static water level: <u>48</u> ft. below land surface Date <u>3-23-75</u>
						10 Pumping level below land surfaces: — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield <u>100</u> g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —
						12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade <u>12"</u>
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <u>94 lb Portland</u> Depth: From <u>4</u> ft. to <u>14</u> ft.
						14 Nearest source of possible contamination: ft. <u>150</u> Direction <u>NW</u> Type <u>Septic Tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
(use a second sheet if needed)			15 Pump: Not installed Manufacturer's name <u>STARITE</u> Model number <u>LP82</u> HP <u>1</u> Volts <u>230</u> Length of drop pipe <u>50</u> ft. capacity <u>30</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation <u>Level</u>  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Hank Bruse Well Serv. 103</u> Business name License No. Address <u>1117 Stuart Pratt</u> Signed <u>Joey Bruse</u> Date <u>6-29-75</u> Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5