

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 10	Township number T 28 S R 14W E/W	Range number 14W E/W
2. Distance and direction from nearest town or city: 3E 1/2S 1/4E of Cullison Street address of well location if in city: Cullison			3. Owner of well: Phillip Lunt R.R. or street: City, state, zip code: Cullison, Kansas 67124			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date 14 July 76 Well depth 172 ft.		
				7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil		0	2	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 172 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
Clay, Tan		2	46	10. Screen: Manufacturer's name W.A. Brown Type Freeflo Dia. 16" Slot 1/8 Length 40' Set between 132' ft. and 172' ft. ft. and <input type="checkbox"/> ft.		
Sand, Fine to coarse and fine gravel		46	70	Gravel pack? yes Size range of material 1/2 x 1/8		
Clay, Gray and tan		70	80	11. Static water level: 97 ft. below land surface Date 1 July 76 mo./day/yr.		
Sand, fine to coarse and medium gravel		80	111	12. Pumping level below land surfaces: 115 ft. after 1 hrs. pumping 900 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m.		
Sand, cemented and clay		111	119	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
Sand, fine to coarse		119	143	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Sand, fine to coarse & medium coarse gravel		143	170	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 40 ft.		
Clay, sandy tan and rock hard		170	186	16. Nearest source of possible contamination: None ft. Direction <input type="checkbox"/> Type None Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay, sandy tan and sand and gravel		186	188	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Floway Model number 12DOL HP 90 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale, red		188	195	18. Elevation: 2015 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks: This well is in a low place, so an earthen pad 2' thick x 18' x 30' long was built around the well and a 5' x 10' x 1' concrete pad poured on top of that making the casing 3' above original ground level. 30293		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name 121 S. Taylor License No. 14 July 76 Address 121 S. Taylor Signed Johnomick Date 14 July 76 Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5