


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>PRATT</u> Fraction <u>SW 1/4 NE 1/4 NE 1/4</u> Section number <u>2</u> Township number <u>T 28 S</u> Range number <u>R 15 W E/W</u>																												
2. Distance and direction from nearest town or city: <u>1 N 1 W OF CULLISON, KS</u>																												
3. Owner of well: <u>MERLE ROSE</u> R.R. or street: City, state, zip code: <u>HAVILAND, KS</u>																												
4. Locate with "X" in section below: Sketch map: 																												
5. Type and color of material																												
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Soil</td> <td>0</td> <td>2</td> </tr> <tr> <td>CLAY, TAN</td> <td>2</td> <td>52</td> </tr> <tr> <td>SAND, FINE TO COARSE</td> <td>52</td> <td>56</td> </tr> <tr> <td>CLAY, TAN</td> <td>56</td> <td>64</td> </tr> <tr> <td>SAND, FINE TO COARSE & MED GRAVEL</td> <td>64</td> <td>78</td> </tr> <tr> <td>CLAY, TAN</td> <td>78</td> <td>104</td> </tr> <tr> <td>SAND, FINE TO COARSE & COARSE GRAVEL</td> <td>104</td> <td>145</td> </tr> <tr> <td>CLAY, TAN</td> <td>145</td> <td>158</td> </tr> </tbody> </table>			From	To	Soil	0	2	CLAY, TAN	2	52	SAND, FINE TO COARSE	52	56	CLAY, TAN	56	64	SAND, FINE TO COARSE & MED GRAVEL	64	78	CLAY, TAN	78	104	SAND, FINE TO COARSE & COARSE GRAVEL	104	145	CLAY, TAN	145	158
	From	To																										
Soil	0	2																										
CLAY, TAN	2	52																										
SAND, FINE TO COARSE	52	56																										
CLAY, TAN	56	64																										
SAND, FINE TO COARSE & MED GRAVEL	64	78																										
CLAY, TAN	78	104																										
SAND, FINE TO COARSE & COARSE GRAVEL	104	145																										
CLAY, TAN	145	158																										
6. Bore hole dia. <u>30</u> in. Completion date <u>21 JUNE 79</u> Well depth <u>145</u> ft.																												
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																												
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																												
9. Casing: Material <u>STL</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>16</u> lbs./ft. Dia. <u>16</u> in. to <u>105</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>105</u> ft. depth gage No. <u>188</u>																												
10. Screen: Manufacturer's name <u>WA BROWN</u> Type <u>FREE FLO</u> Dia. <u>16"</u> Slot/gauze <u>48</u> Length <u>40'</u> Set between <u>105'</u> ft. and <u>145'</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 X 3/4</u>																												
11. Static water level: <u>70</u> ft. below land surface Date <u>21 JUNE 79</u> mo./day/yr.																												
12. Pumping level below land surfaces: <u>88</u> ft. after <u>1</u> hrs. pumping <u>800</u> g.p.m. <u>92</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. Estimated maximum yield <u>1600</u> g.p.m.																												
13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <u>21 JUNE 79</u> mo./day/yr.																												
14. Well head completion: <u>12</u> inches above grade <input type="checkbox"/> Pitless adapter																												
15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.																												
16. Nearest source of possible contamination: <u>NONE</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No																												
17. Pump: Not installed Manufacturer's name <u>JOHNSON</u> Model number _____ HP _____ Volts _____ Length of drop pipe <u>125</u> ft. capacity <u>900</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																												
(Use a second sheet if needed)																												
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>6' X 12' X 8" Concrete Slab was poured at Surface</u>																											
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Central Well & Pump 325</u> Business name _____ License No. _____ Address <u>Box 1032 PRATT, KS</u> Signed <u>Ed Monomich</u> Date <u>25 JUNE 79</u> Authorized representative																												

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5