


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Receiv #1

1. Location of well:	County: <u>Pratt</u>	Fraction: <u>C 1/4 NW 1/4 SW 1/4</u>	Section number: <u>12</u>	Township number: <u>T 28</u>	Range number: <u>S 15</u>	<u>X</u>
2. Distance and direction from nearest town or city: <u>Collis, KS, 1 South 3/4 West North to</u>			3. Owner of well: <u>Rains - Williams</u>			
Street address of well location if in city: <u>LOCATION</u>			R.R. or street: <u>435 PAGE CT.</u>			
4. Locate with "X" in section below:			City, state, zip code: <u>Wichita, Kans. 67202</u>			
Sketch map:			6. Bore hole dia. <u>9</u> in. Completion date <u>9-3-79</u>			
			X Well depth <u>140</u> ft.			
			7. Cable tool <u>X</u> Rotary <u>X</u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary <u> </u>			
			8. Use: Domestic <u> </u> Public supply <u> </u> Industry <u> </u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other <u> </u>			
			9. Casing: Material <u> </u> Weight: Above or below <u> </u> Threaded <u> </u> Welded <u>X</u> Surface <u>12</u> in. RMP <u> </u> PVC <u>X</u> Weight <u>278.3</u> lbs./ft. Dia. <u>5</u> in. to <u>140</u> ft. depth Wall Thickness: inches or <u> </u> Dia. in. to <u> </u> ft. depth Gauge No. <u>265</u>			
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u> </u>	
<u>Soil</u>			<u>0</u>	<u>6</u>	<u> </u>	
<u>Clay</u>			<u>6</u>	<u>30</u>	Type <u>SAW</u> Dia. <u>5</u>	
<u>Fine Sand</u>			<u>30</u>	<u>50</u>	Slot/gauze <u>1/4</u> Length <u>20</u>	
<u>Clay</u>			<u>50</u>	<u>90</u>	Set between <u>120</u> ft. and <u>120</u> ft.	
<u>Gravel</u>			<u>90</u>	<u>140</u>	Gravel pack? <u> </u> Size range of material <u>1/4-1/8</u>	
					11. Static water level: <u>91</u> ft. below land surface Date <u>9-3-79</u>	
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
					13. Water sample submitted: <u> </u> mo./day/yr. Yes <u> </u> No <u>X</u> Date <u> </u>	
					14. Well head completion: Pitless adapter <u>12</u> Inches above grade	
					15. Well grouted? <u>yes</u> With: Neat cement <u>X</u> Bentonite <u> </u> Concrete <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.	
					16. Nearest source of possible contamination: <u>None</u> ft. Direction Type <u> </u> Well disinfected upon completion? Yes <u> </u> No <u>X</u>	
					17. Pump: <u>X</u> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other <u> </u>	
			(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Myers Water Well</u> <u>143</u> Business name <u>Great Bend KS 67530</u> License No. <u> </u> Address <u> </u> Signature <u> </u> Date <u>9-3-79</u> Authorized representative			
Topography: <u> </u> Hill <u>X</u> Slope <u> </u> Upland <u> </u> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5