USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number	
1. Location of well:	Pratt	1/4 1/4 NW			33	T 28 S	R 15 E/W	
					ner of well: Lloyd Smith			
Street obdiress of well location it in city: R.R. or street: City, state, zip code:					code: Ch	Cullison, Ks.		
4. Locate with "X" in section below: Sketch map:					-320. ()	6. Bore hole dia. 29 in.	. Completion date	
N N						Well depth 181 ft.	12-16-76	
	!					7 Cable tool X_ Rotary		
E - SW SE					8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material Steel_Height: Above or below			
						*1 1 W-14-4 *	18	
S						RMP PVC		
5 Turn and solar of meterial				From	То	Dia in. t <u>181</u> ft. dep Dia in. to ft. dep	in wan inckness; inches or	
5. Type and color of material				110		10. Screen: Manufacturer's n	name	
Top Soil				0	4	Type #/// Stee		
Brown Clay				4	9	Slor/gauze 3/16 Set between 141	2 Length	
Sand and Gravel				9	49	Gravel pack? Size ra	indft.	
				49	57	11. Static water level:	mo./day/yr.	
Brown and White Clay				47	71	ft. below land sur	face Date <u>8-9-76</u>	
Sand and Gravel				57	183	12. Pumping level below land 46 ft. after 1	surfaces: ars. pumping 800 g.p.m.	
Brown Clay				183	195	ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Yellow, Brown, Gray Clay				195	199	13. Water sample submitted:	mo./day/yr.	
SAnd and Gravel				199	203	X Yes No	Date 8 -9-70	
Hard, White Rock				203	203 ¹ / ₂	Pitless adapter	Inches above grade	
Sand and Gravel, Streaks of Red				203	213	15. Well grouted? With: Neat cement	Bentonite _X Concrete	
Red Bed				1213	215	Depth: From ft. to ft. to	(
						16. Nearest source of possible ft. 200 Direction Well disinfected upon comple		
						17. Pump:	Not installed	
						Manufacturer's name	WaliaRa	
						Model number $8DH10$ Length of drop pipe 120	HP 100 Volts Tr. capacity 1000 g.p.m.	
						Туре:		
						Submersible Jet	Turbine Reciprocating	
	(Use a second s	heet if needed)		,,	1	Centrifugal	Other O	
18. Elevation: 19. Remarks: 26910					20. Water well contractor's of This well was drilled under m	errification:		
Towards and the second					is true to the best of my know Rosencrantz-Ben			
- HIII 20 15 35 NP					Business name	License No.		
Slope	Slope X Upland					Fredie	Bend. Ks.	
Valley						Signed Authorized rep	resentative Date	
Forward the white his	ue and pink copies to the Department	of Health and Environment					Form WWC-5	