

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Nowia	Fraction C/NE 1/4 1/4 1/4	Section number 3	Township number T 28 S R 16 E/W	Range number																								
2. Distance and direction from nearest town or city: 2 N 3E 1/4S OF Haviland Street address of well location if in city: W side of Rd.			3. Owner of well: Leonard Harper R.R. or street: 2412 Bdwy. City, state, zip code: Great Bend, Ks.																											
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date 8-20-75 Well depth 150 ft.																										
		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>5. Type and color of material</th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Top Soil</td> <td>0</td> <td>2</td> </tr> <tr> <td>Brown Clay</td> <td>2</td> <td>7</td> </tr> <tr> <td>Red Clay & Fine Sand</td> <td>7</td> <td>65</td> </tr> <tr> <td>Sand & Gravel</td> <td>65</td> <td>85</td> </tr> <tr> <td>Clay</td> <td>85</td> <td>87</td> </tr> <tr> <td>Sand & Gravel</td> <td>87</td> <td>148</td> </tr> <tr> <td>Clay</td> <td>148</td> <td>150</td> </tr> </tbody> </table>		5. Type and color of material	From	To	Top Soil	0	2	Brown Clay	2	7	Red Clay & Fine Sand	7	65	Sand & Gravel	65	85	Clay	85	87	Sand & Gravel	87	148	Clay	148	150	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				5. Type and color of material	From	To																								
Top Soil	0	2																												
Brown Clay	2	7																												
Red Clay & Fine Sand	7	65																												
Sand & Gravel	65	85																												
Clay	85	87																												
Sand & Gravel	87	148																												
Clay	148	150																												
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 150 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7																											
				10. Screen: Manufacturer's name Doerrs Type Steel Dia. 1 1/2 Slot/gauze 3/16 Length 40 Set between 110 ft. and 150 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8																										
				11. Static water level: <input type="checkbox"/> mo./day/yr. 64 ft. below land surface Date 8-7-75																										
				12. Pumping level below land surfaces: 66 ft. after 1 hrs. pumping 1000 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 400 g.p.m.																										
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-7-75																										
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade																										
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.																										
				16. Nearest source of possible contamination: ft. 74 Direction NEW Type Septic Tank Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No																										
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name WLR Model number 5CM-12 HP 100 Volts <input type="checkbox"/> Length of drop pipe 125 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
				(Use a second sheet if needed)																										
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz - Bemis 134 Business name License No. Address Great Bend Ks Signed Freda Nodder Date 9/13/75 Authorized representative																										
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																														

T 28 S R 16 E/W
 1/4 1/4 1/4
 C/NE