

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 C 1/4 NW 1/4	Section number 19	Township number T 28 S R 16	Range number EW
2. Distance and direction from nearest town or city: 1 mi south 3/4 mi west 1/4 mi south from Haviland				3. Owner of well: Max Hoeme R.R. or street: City, state, zip code: Preston, Kansas 67569		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 			6. Bore hole dia. 29 in. Completion date _____ Well depth 201 ft. 4/15/77	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Sandy top soil		0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Brown clay		4	51	9. Casing: Material steel Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 201 ft. depth; Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth; gage No. _____ 7ga		
Sandy brown clay		51	68	10. Screen: Manufacturer's name Doerrs Type _____ Dia. 16" m/c Slot _____ 3/16 Length 52' Set between 149 ft. and 201 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material: _____ 1/2 to 3/4		
Sand		68	74	11. Static water level: _____ mo./day/yr. 130 ft. below land surface Date 2/2/77		
Sandy brown clay		74	90	12. Pumping level below land surfaces: 124 ft. after 1 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.		
Sandy brown clay mix		90	93	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 2/2/77		
Mid. coarse sand gravel to coarse sand				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
gravel		93	200	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Brown clay		200	203	16. Nearest source of possible contamination: ft. 1/2 mi Direction NW Type septic Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(Use a second sheet if needed)				17. Pump: _____ Not installed Manufacturer's name W.L.R. Model number 6-12CH HP 80 Volts _____ Length of drop pipe 170 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Kansas 67530 Signed Shady P. Lopez Date 6/4/77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 28 S R 16 E Sec 19

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5