

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Kiowa Fraction SE 1/4 SW 1/4 SE 1/4 Section number 8 Township number T 28-34 S Range number R 17 (W)			
2. Distance and direction from nearest town or city: 6.5 N Greensburg Kansas Street address of well location if in city:		3. Owner of well: Clayton Batman R.R. or street: Haviland Kans City, state, zip code:	
4. Locate with "X" in section below: Sketch map:		6. Bore hole dia. 8 3/4 in. Completion date 7-22-78 Well depth 120 ft.	
<p>1 Mile 1 Mile</p>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		9. Casing: Material Pl Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 120 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; (gauge) No. 200	
		10. Screens: Manufacturer's name Sun Power Plastics Type RMP Dia. 5" Slot/gauge 1/8 Length 20' Set between 100 ft. and 120 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4x5	
		11. Static water level: _____ mo./day/yr. 66 ft. below land surface Date 7-22-78	
		12. Pumping level below land surfaces: 66 ft. after 4 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.	
		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
		15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
		16. Nearest source of possible contamination: ft. 150 Direction NE Type Hoes Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
		17. Pump: _____ Not installed Manufacturer's name FACET & WALLING Model number 720 12 HP 24 Volt 220 Length of drop pipe 84 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hayes Water Well 224 Business _____ License No. _____ Address Greensburg, Kansas Signed Carl Hayes Date 7-22-78 Authorized representative	
18. Elevation:	19. Remarks:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			

28-17-8
 T
 R
 W
 Sec
 1/4 1/4 1/4
 SE 1/4 SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5