

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 22	Township number T 28 S R 17 W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Milton Ross R.R. or street: City, state, zip code: Haviland, Kansas			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 15 AUG 79 Well depth 200 ft.		
		<p style="text-align: center;">X well DRAINAGE</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy soil		0	2	9. Casing: Material STL Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32.7 lbs./ft. Dia 16 in. to 140 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
Clay, tan and sandy		2	50	10. Screen: Manufacturer's name WA BROWN Type 1/2" Flow Dia. 16" Slot/gauze 1/8 Length 40' Set between 140 ft. and 180 ft. ft. and <input type="checkbox"/> ft.		
Sand, fine and silty		50	60	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 3/16		
Sand, fine and tan clay mixed		60	82	11. Static water level: <input type="checkbox"/> mo./day/yr. 105 ft. below land surface Date 15 AUG 79		
Sand, fine to coarse and coarse gravel		82	108	12. Pumping level below land surfaces: 115 ft. after 1 hrs. pumping 800 g.p.m. 123 ft. after 1 hrs. pumping 1200 g.p.m. Estimated maximum yield 1600 g.p.m.		
Clay, tan and gray with sand and gravel		108	120	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Sand, fine to coarse and medium gravel		120	150	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
150 Sand, fine to coarse and coarse gravel		150	180	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Clay, tan and sandy		180	184	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type NONE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay, yellow		184	190	17. Pump: Manufacturer's name Summons Not installed Model number Sm13 HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Shale, black		190	200	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump Inc. 325 Business name License No. Address P.O. Box 1032 Pratt, Kansas Signed Phononovich Date OCT 79 Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		8' x 23' x 8" slab-poured at surface				

T 28 S R 17 W E/W
 Sec 22 NW SE NW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3