

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KIOWA	Fraction SE 1/4 NW 1/4 SW 1/4	Section number 31	Township number T 28 S	Range number R 17 W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: William Keller R.R. or street: City, state, zip code: Greensburg, Ks			
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 30 in. Completion date 17 Jan 78 Well depth 215 ft.			
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 215 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188			
			10. Screen: Manufacturer's name Triello Type <input type="checkbox"/> Dia. 16" Slot/gauze 1/8 Length 40 Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. 175 ft. and 215 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 1/2			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 142 ft. below land surface Date 17 Jan 78			
			12. Pumping level below land surfaces: 158 ft. after 1 hrs. pumping 800 g.p.m. 164 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 1400 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Above Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: <input type="checkbox"/> Nat installed Manufacturer's name Layne Model number <input type="checkbox"/> HP 110 Volts <input checked="" type="checkbox"/> Length of drop pipe 180 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks: 6' x 12' x 8" slab poured at surface				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name License No. Address 124 S. Taylor Pratt Signed R. J. J. J. J. Date 22 July 78 Authorized representative				

T
R
E
S
E
C
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5