

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County KIOWA Fraction SW 1/4 NE 1/4 SE 1/4 Section number 22 Township number T 28 S R 18 W Range number E 1/4	
2. Distance and direction from nearest town or city: 1E 1 1/2 S OF GREENSBURG, KS 3. Owner of well: HAROLD SCHMIDT Street address of well location if in city: GREENSBURG, KS R.R. or street: City, state, zip code: GREENSBURG, KS	
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>1 Mile</p> <p>1 Mile</p> </div> <div> <p>Sketch map:</p> <p style="text-align: center;">WATER WELL X</p> <p style="text-align: center;">↓ ↓ ↓ DRAINAGE</p> </div> </div>	
6. Bore hole dia. 30 in. Completion date 21 MAR 77 Well depth 150 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material STL Height (Above) or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 130 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188	
10. Screen: Manufacturer's name WA BROWN Type FRELO Dia. 16" Slot/gauze 48 Length 20' Set between 130 ft. and 150 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-1/2	
11. Static water level: 112 ft. below land surface Date 18 MAR 77 mo./day/yr.	
12. Pumping level below land surfaces: 119 ft. after 2 hrs. pumping 307 g.p.m. 129 ft. after 1 hrs. pumping 791 g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name FLOWAY Model number _____ HP 60 Volts _____ Length of drop pipe 140 ft. capacity 400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 5'X10' CONCRETE SLAB AT SURFACE
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CENTRAL Well & Pump 325 Business name License No. Address 121 S. TAYLOR PRATT Signed Photomichel Date 21 MAR 77 Authorized representative	

T 28 S R 18 W E 1/4
 Sec 22
 SW NE SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5