


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County Kiowa		Fraction c 1/4 SW 1/4		Section number 35		Township number 28		Range number 18 W	
2. Distance and direction from nearest town or city: from Greensburg 2 3/4 south 3/4 east				3. Owner of well: Bill Keller R.R. or street: Greensburg, Ks. 67054 City, state, zip code:					
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 		6. Bore hole dia. 29 in. Completion date _____ Well depth 200 ft. 7-26-76			
5. Type and color of material				From		To		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
								8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input checked="" type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top soil				0		3		9. Casing: Material steel Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 200 depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. 7	
Clay				3		70		10. Screen: Manufacturer's name _____ Doerrs Type steel Dia. 16 Slot/gage size 3/16 Length 60 Set between 140 ft. and 200 ft. _____ ft. and _____ ft.	
Sand and gravel				70		77		Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8 - 1/2	
Clay				77		97		11. Static water level: _____ mo./day/yr. 3/4 125 ft. below land surface Date 7-9-76	
Good sand and gravel				97		176		12. Pumping level below land surfaces: 134 ft. after 2 hrs. pumping 600 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1000 g.p.m.	
Clay				176		177		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 7-9-76	
Sand and fine sand little clay				177		200		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
Clay				200		210		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Good sand and gravel				210		213		16. Nearest source of possible contamination: ft. 5 mi Direction North Type gas well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Yellow clay				213		220		17. Pump: _____ Not installed Manufacturer's name Layne Fowler Model number 7-10rb HP 80 Volts _____ Length of drop pipe 160 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Blue shale				220		240			
(Use a second sheet if needed)									
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosnecrantz-Bemis 134 Business name Great Bend, Ks. 67530 License No. _____ Address _____ Signed S. Kilgore Date 7-20-76 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5