

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Kiowa</b>	Fraction <b>NE 1/4 1/4 1/4</b>	Section number <b>36</b>	Township number <b>T 28 S R 18</b>	Range number <b>18</b>
2. Distance and direction from nearest town or city: <b>Greensburg, 2 1/2 Mi. S., 3/4 Mi. E.</b> <small>Street address of well location if in city:</small>			3. Owner of well: <b>Gene West</b> R.R. or street: <b>Greensburg, Kansas</b> City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: <b>Well No. 2 (TH 1-76)</b>		
5. Type and color of material			From	To	6. Bore hole dia. <u>30</u> in. Completion date _____ Well depth <u>186</u> ft. <u>9-17-76</u>
Soil			0	2	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Brown clay			2	30	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine sand w/clay			30	38	9. Casing: Material <u>Stl</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>24</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.75</u> lbs./ft. Dia. <u>16</u> in. to <u>148</u> ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. <u>188</u>
Fine to med. sand			38	49	10. Screen: Manufacturer's name <u>Doerr</u> <u>Metal Products</u> Type <u>Stl.</u> Dia. <u>16"</u> Slot/gauze <u>1/8</u> Length <u>40'</u> Set between <u>146</u> ft. and <u>186</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 to 3/8</u>
Brown clay			49	63	11. Static water level: _____ mo./day/yr. <u>120</u> ft. below land surface Date <u>9-14-76</u>
Brown clay w/sand			63	71	12. Pumping level below land surfaces: <u>138</u> ft. after <u>4 1/2</u> hrs. pumping <u>815</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>800</u> g.p.m.
Med. to coarse sand & gravel			71	84	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Brown clay			84	88	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>24</u> Inches above grade
Brown clay			88	125	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Med. to coarse sand & gravel w/clay			125	129	16. Nearest source of possible contamination: ft. <u>2500</u> Direction <u>West</u> Type <u>Furn</u> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
Med. to coarse sand & gravel			129	131	17. Pump: _____ Not installed Manufacturer's name <u>Layne</u> Model number <u>12KL</u> HP <u>80</u> Volts _____ Length of drop pipe <u>140</u> ft. capacity <u>700</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Brown clay			131	179	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne Western Co. 102</b> Business name _____ License No. _____ Address <u>Wichita, Kansas</u> Signed <u>[Signature]</u> Date <u>9/30/76</u> Authorized representative
Brown clay			179	181	
Med to coarse sand & gravel			181	187	
Brown clay			187	191	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

28 18 W E  
 36 CUE  
 1/4 1/4 1/4  
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5