

1 LOCATION OF WATER WELL: | Fraction | Section Number | Township Number | Range Number
 COUNTY: **KIOWA** | **SW 1/4 SE 1/4 SE 1/4** | **07** | **T 28 S** | **R 18 W**

Distance and direction from nearest town or city street address of well if located within city?
FROM GEENSBURG; APPX 3/4 MILE NORTH & 1000' WEST

2 WATER WELL OWNER: **H. D. GRIFFIN**
 RR#, St. Address, Box #: **301 N. MASON** Board of Agriculture, Division of Water Resources
 City, State, ZIP code: **CARROLLTON, MO 67633-** Application Number: **20069085**

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: | 4 DEPTH OF COMPLETED WELL 187 ELEVATION: 0
 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.
 --- | | | | |
 / \ | | | | | WELL'S STATIC WATER LEVEL 51 ft. below land surface measured on mo/day/yr 10/14/06
 | | | | | Pump test data: Well water was 89 ft. after 4 hours pumping 1200 gpm
 1 | --- NW --- NE --- | | | | | Estimated Yield 0 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm
 M | | | | | | | | | | |
 i W | --- --- --- E | | | | | Bore Hole Diameter 24 in. to 187 ft., and in. to 0 ft.
 l | | | | | | | | | | |
 e | | | | | | | | | | |
 | | | | | | | | | | |
 \ / | | | | | WELL WATER TO BE USED AS: **04 INDUSTRIAL**
 --- | --- SW --- SE --- | | | | |
 | | | | | Was a chemical/bacteriological sample submitted to department? **No** ;
 \ / | | | | | If yes, mo/day/yr sample was submitted Water well disinfected? **Yes**
 --- | --- --- --- --- X --- | | | | |

5 TYPE OF BLANK CASING USED: **01 STEEL** CASING JOINTS: **WELDED**
 Blank casing diameter 16 in. to 187 ft., Dia in. to 0 ft., Dia in. to 0 ft.
 Casing height above land surface 12 in., weight 37 lbs/ft. Wall thickness or gauge No. .219
 TYPE OF SCREEN OR PERFORATION MATERIAL: **01 STEEL**
 SCREEN OR PERFORATION OPENINGS ARE: **01 CONT. SLOT**

SCREEN PERFORATED INTERVALS: From 77 ft. to 177 ft., From 0 ft. to 0 ft.
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.
 GRAVEL PACK INTERVALS: From 20 ft. to 187 ft., From 0 ft. to 0 ft.
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL **03 BENTONITE**
 Grout Intervals: From 0 ft. to 20 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.
 What is the nearest source of possible contamination: **NONE OBSERVED**
 Direction from well? How many feet? **0**

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	02 SILT			
2	29	04 SANDY CLAY			
29	35	07 FINE SAND			
35	52	04 SANDY CLAY			
52	134	05 SAND 11 GRAVEL			
134	156	07 FINE SAND 08 MEDIUM SAND 01 CLAY			
156	177	04 SANDY CLAY 05 SAND			
177	200	19 SHALE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) **10/13/06** and this record is true to the best of my knowledge and belief. Kansas
 Water Well Contractor's License No. **145** This Water Well Record was completed on (mo/day/yr) **12/22/06**
 under the business name of **HENKLE DRILLING & SUPPLY** by (signature) *Bruce J. Reichmuth*