

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: kiowa	Fraction: SW 1/4 SE 1/4 SW 1/4	Section number: 35	Township number: T 28 S R 19 W	Range number: 19 W
2. Distance and direction from nearest town or city: 3 1/2 W 3 S Greensburg			3. Owner of well: Richard Unruh R.R. or street: Greensburg Kansas City, state, zip code: Greensburg Kansas			
4. Locate with "X" in section below:		Sketch map:		<input checked="" type="checkbox"/> Bore hole dia. 3 1/4 in. Completion date 4-7-78 Well depth 133 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PI Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. 133 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 200		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Sax Flower Plastics		
Top Soil		0	2	Type RMP Dia. 5		
Reddish Clay		2	14	Slot gauze 1/8 Length 30		
Tan Clay		14	53	Set between 113 ft. and 133 ft.		
BR. Clay		53	61	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 x 3/4		
Tan Clay		61	86	11. Static water level: _____ mo./day/yr. 97 ft. below land surface Date 4-7-78		
Gravel		86	116	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 25 g.p.m.		
Clay		116	118	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Gravel		118	133	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 18 ft.		
				16. Nearest source of possible contamination ft. 120 Direction SW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Flint & Walling Model number 7B12 HP 3/4 Volt 230 Length of drop pipe 115 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CARL HAYSE WATER WELL SERV. 224 License No. _____ Address: 609 S. Maple, Greensburg, Kans. Signed: Carl Hayse Date: 4-7-78 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

28
 19
 35
 SW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5