WATER WELL RECORD Form WWC-5 KSA 82a-1212

---

1 LOCATION OF WATER WELL:

	Fraction	Section Number	Township Number	Range Number
COUNTY: KIOWA	NW 1/4 NW 1/4 NE 1/4	32	T 28 S	R 19 W

Distance and direction from nearest town or city street address of well if located within city?
1 MILE SOUTH, 3 MILES EAST OF MULLINVILLE

---

2 WATER WELL OWNER: SHERER, RICK
RR#, St. Address, Box # : RR 1
City, State, ZIP code : MULLINVILLE, KS   67109-

Board of Agriculture, Division of Water Resources
Application Number:

---

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

```
/ \    |     |  X  |
1    ---- NW ----- ---- NE -----
M
i  W  |------|------|------|------| E
l
e    ---- SW ----- ---- SE -----
\ /    |     |     |
```

4 DEPTH OF COMPLETED WELL 180 ELEVATION: 0
Depth(s) Groundwater Encountered   1.   0 ft.   2.   0 ft.   3.   0 ft.

WELL'S STATIC WATER LEVEL   140 ft. below land surface measured on mo/day/yr 06/15/05
Pump testdata: Well water was   0 ft. after   0 hours pumping   0 gpm

Estimated Yield   0 gpm: Well water was   0 ft. after   0 hours pumping   0 gpm

Bore Hole Diameter   8.75 in. to 180 ft., and   in. to   0 ft.

WELL WATER TO BE USED AS: **LIVESTOCK**

Was a chemical/bacteriological sample submitted to department? **No** ;
If yes, mo/day/yr sample was submitted   Water well disinfected? **Yes**

---

5 TYPE OF BLANK CASING USED: PVC   CASING JOINTS: **GLUED**
Blank casing diameter   5   in. to 160 ft., Dia   in. to   0 ft., Dia   in. to   0 ft.
Casing height above land surface   12 in.,   weight   0 lbs/ft. Wall thickness or gauge No. 21
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 160 ft. to 180 ft., From   0 ft. to   0 ft.
                                From   0 ft. to   0 ft., From   0 ft. to   0 ft.
GRAVEL PACK INTERVALS: From 25 ft. to 180 ft., From   0 ft. to   0 ft.
                                From   0 ft. to   0 ft., From   0 ft. to   0 ft.

---

6 GROUT MATERIAL   BENTONITE
Grout Intervals: From   4 ft. to 25 ft., From   0 ft. to   0 ft., From   0 ft. to   0 ft.
What is the nearest source of possible contamination: **SEPTIC TANK**
Direction from well? **EAST**   How many feet? 2500

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	6	BROWN CLAY			
6	93	TAN CLAY			
93	142	SAND AND GRAVEL			
142	165	TAN CLAY			
165	178	BROWN ROCK SANDSTONE			
178	180	GRAY SHALE			

---

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 06/10/05 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 653   This Water Well Record was completed on (mo/day/yr) 06/22/05
under the business name of **DAN HAYSE WATER WELL SERV**   by (signature) *Dan Hayse*