

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: SEDGWICK		SW ¼ SW ¼ SE ¼		21		T 28 S		R 2 W 4W	
Distance and direction from nearest town or city?					Street address of well if located within city?				
					17518 W. 55th S. S., Wichita, Ks.				
2 WATER WELL OWNER: Linn Homes Spec. House									
RR#, St. Address, Box # : 6827 E. Harry					Board of Agriculture, Division of Water Resources				
City, State, ZIP Code : Wichita, Ks.					Application Number:				
3 DEPTH OF COMPLETED WELL: 45 ft. Bore Hole Diameter: 11 in. to ft., and in. to ft.									
Well Water to be used as:									
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well	
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)	
				7 Lawn and garden only		10 Observation well		Spec. House	
Well's static water level: 17 ft. below land surface measured on					12 month 3 day 80 year				
Pump Test Data					Well water was ft. after hours pumping gpm				
Est. Yield gpm: Well water was ft. after hours pumping gpm									
4 TYPE OF BLANK CASING USED:									
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: Glued X Clamped	
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		Welded	
				7 Fiberglass				Threaded	
Blank casing dia: 5 in. to 25 ft., Dia in. to ft., Dia in. to ft.									
Casing height above land surface: 12 in., weight lbs./ft. Wall thickness or gauge No. 200									
TYPE OF SCREEN OR PERFORATION MATERIAL:									
1 Steel		3 Stainless steel		5 Fiberglass		7 PVC		10 Asbestos-cement	
2 Brass		4 Galvanized steel		6 Concrete tile		8 RMP (SR)		11 Other (specify)	
						9 ABS		12 None used (open hole)	
Screen or Perforation Openings Are:					5 Gauzed wrapped 8 Saw cut .06 11 None (open hole)				
1 Continuous slot		3 Mill slot		6 Wire wrapped		9 Drilled holes			
2 Louvered shutter		4 Key punched		7 Torch cut		10 Other (specify)			
Screen-Perforation Dia: 5 in. to 45 ft., Dia in. to ft., Dia in. to ft.									
Screen-Perforated Intervals: From 25 ft. to 45 ft., From ft. to ft., From ft. to ft.									
Gravel Pack Intervals: From 14 ft. to 45 ft., From ft. to ft., From ft. to ft.									
5 GROUT MATERIAL:									
1 Neat cement		2 Cement grout		3 Bentonite		4 Other			
Grouted Intervals: From 40 ft. to 14 ft., From ft. to ft., From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well	
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well	
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)	
						13 Watertight sewer lines		NONE APPARENT	
Direction from well: How many feet ?					Water Well Disinfected? Yes X No				
Was a chemical/bacteriological sample submitted to Department? Yes No X					If yes, date sample was submitted month day year: Pump Installed? Yes No				
If Yes: Pump Manufacturer's name					Model No. HP Volts				
Depth of Pump Intake ft.					Pumps Capacity rated at gal./min.				
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 12 month 3 day 80 year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on 3 month 2 day 81 year under the business name of Harp Well & Pump Serv., Inc. by (signature) M. Arnold									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG		FROM TO		LITHOLOGIC LOG	
		0 3		Topsoil					
		3 13		Clay					
		13 20		Fine Sand					
		20 45		Grey Shale					
ELEVATION:									
Depth(s) Groundwater Encountered 1. 17 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									

OFFICE USE ONLY

T

R

EW

SEC

SW ¼ SE ¼