USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| 1. Location of well: | County | Fraction | Section number | Township number | Range number |
|---|---|---|---|---|---|
| | SEDGWICK | 1/4 NW 1/4 SE 1/4 | 21 | T 28 S | R 2W E/W |

2. Distance and direction from nearest town or city: ¼ West of 167th West on 55th St. So. then ½ North
Street address of well location if in city: on the West side of the Road.

3. Owner of well: George Clark
R.R. or street: 357 Lulu
City, state, zip code: Wichita, Kansas

4. Locate with "X" in section below: Sketch map: Goddard, Kansas

N — NW — NE — W — E — X — SW — SE — S — 1 Mile — 1 Mile

6. Bore hole dia. 11 in. Completion date ____
Well depth 35 ft. 4-19-78

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material styrene Height: Above or below
Threaded ____ Welded gl Surface 12 in.
RMP X PVC ____ Weight ____ lbs./ft.
Dia. 5 in. to 35 ft. depth Wall Thickness: inches or
Dia. ____ in. to ____ ft. depth gage No. .200

| 5. Type and color of material | From | To |
|---|---|---|
| Topsoil | 0 | 2 |
| Brown Clay | 2 | 9 |
| Fine Sand mixed with Gray Clay | 9 | 16 |
| Fine Sand | 16 | 22 |
| Medium Fine Sand | 22 | 30 |

(Use a second sheet if needed)

10. Screen: Manufacturer's name Sunflower Plastic
Type styrene Dia. 5"
Slot/gauze .06 Length 10'
Set between 25 ft. and 35 ft.
____ ft. and ____ ft.
Gravel pack? yes Size range of material ¼-1/8"

11. Static water level: mo./day/yr.
15 ft. below land surface Date 4-19-78

12. Pumping level below land surfaces:
____ ft. after ____ hrs. pumping ____ g.p.m.
____ ft. after ____ hrs. pumping ____ g.p.m.
Estimated maximum yield ____ g.p.m.

13. Water sample submitted: mo./day/yr.
__ Yes __ No Date ____

14. Well head completion:
X Pitless adapter 12 Inches above grade

15. Well grouted? yes 1-2 fine sand mix
With: ____ Neat cement ____ Bentonite X Concrete
Depth: From 40" ft. to 14 ft.

16. Nearest source of possible contamination: NONE
ft. ____ Direction ____ Type ____
Well disinfected upon completion? X Yes ____ No

17. Pump: ____ Not installed
Manufacturer's name Sta-Rite
Model number 8P4C02 HP ½ Volts 230
Length of drop pipe 30 ft. capacity 8 g.p.m.
Type:
X Submersible ____ Turbine
____ Jet ____ Reciprocating
____ Centrifugal ____ Other

18. Elevation:
Topography:
____ Hill
X Slope
____ Upland
____ Valley

19. Remarks:
Septic System not installed when the well drilled .
No apparent source for contamination.

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Harp Well & Pump License No. 236
Address Wichita, Kansas
Signed M. Arnold Date 5-20-78
Authorized representative

28 T 2 R (W) E 21 Sec NWSE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023