

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number					
County: SEDGWICK		SW ¼ NE ¼ NE ¼		25		T 28 S		R 2 W 7W					
Distance and direction from nearest town or city? 2 S. of K-42 on 119th W., ¼ W. on W. side of Rd., Goddard, Ks.				Street address of well if located within city?									
2 WATER WELL OWNER: Roman Klausmeyer													
RR#, St. Address, Box #: R#1				Board of Agriculture, Division of Water Resources									
City, State, ZIP Code: Goddard, Ks.				Application Number:									
3 DEPTH OF COMPLETED WELL: 138 ft. Bore Hole Diameter: 30 in. to ft., and in. to ft.													
Well Water to be used as:													
1 Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well					
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)					
				7 Lawn and garden only		10 Observation well							
Well's static water level: 28 ft. below land surface measured on 12 month 31 day 80 year													
Pump Test Data: Well water was ft. after hours pumping. gpm													
Est. Yield gpm: Well water was ft. after hours pumping. gpm													
4 TYPE OF BLANK CASING USED:													
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: Glued Clamped X					
2 PVC		4 ABS		6 Asbestos-Cement TRANSITE		9 Other (specify below)		Welded					
				7 Fiberglass				Threaded					
Blank casing dia: 16 in. to 102 in. to ft., Dia in. to ft.													
Casing height above land surface: 12 in., weight 37 lbs./ft. Wall thickness or gauge No. 3/4"													
TYPE OF SCREEN OR PERFORATION MATERIAL:													
1 Steel		3 Stainless steel		5 Fiberglass		8 RMP (SR)		11 Other (specify)					
2 Brass		4 Galvanized steel		6 Concrete tile		9 ABS		12 None used (open hole)					
Screen or Perforation Openings Are:													
1 Continuous slot		3 Mill slot		5 Gauzed wrapped		8 Saw cut TRANSITE		11 None (open hole)					
2 Louvered shutter		4 Key punched		6 Wire wrapped JOHNSON		9 Drilled holes							
				7 Torch cut		10 Other (specify)							
Screen-Perforation Dia: 16 in. to 138 in. to ft., Dia in. to ft.													
Screen-Perforated Intervals: From 102 ft. to 128 TRANSITE ft., From ft. to ft.													
From 128 ft. to 138 JOHNSON ft., From ft. to ft.													
Gravel Pack Intervals: From 10 ft. to 138 ft., From ft. to ft.													
From ft. to ft., From ft. to ft.													
5 GROUT MATERIAL:													
1 Neat cement		2 Cement grout		3 Bentonite		4 Other							
Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.													
What is the nearest source of possible contamination:													
1 Septic tank		4 Cess pool		7 Sewage lagoon		11 Fertilizer storage		14 Abandoned water well					
2 Sewer lines		5 Seepage pit		8 Feed yard		12 Insecticide storage		15 Oil well/Gas well					
3 Lateral lines		6 Pit privy		9 Livestock pens		13 Watertight sewer lines		16 Other (specify below)					
								NONE APPARENT					
Direction from well How many feet ? Water Well Disinfected? Yes X No													
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted month day year: Pump Installed? Yes No X													
If Yes: Pump Manufacturer's name Model No. HP Volts													
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.													
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other													
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 12 month 31 day 80 year													
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236													
This Water Well Record was completed on 3 month 13 day 1981 year under the business name of Harp Well & Pump Serv., Inc. by (signature) M. Arnold													
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:													
		FROM		TO		LITHOLOGIC LOG		FROM		TO		LITHOLOGIC LOG	
		0		98		Clay							
		98		105		Fine Sand							
		105		117		Sand and Gravel							
		117		119		Clay							
		119		138		Sand and Gravel							
ELEVATION:													
Depth(s) Groundwater Encountered 1. 28 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)													
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.													

OFFICE USE ONLY

T

28

R

2

EW

SEC.

26

Sub

NE

NE

NE