

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 17	Township number T 28 S R 20	Range number XXW
2. Distance and direction from nearest town or city: 1 m. North, 3 m. West, 1/2 m. NW, of Mullinville, Ks. Street address of well location if in city:				3. Owner of well: Norval Ralston R.R. or street: City, state, zip code: Mullinville, Ks. 67109		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 108 ft. 6-15-79	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top Soil		0	4	9. Casing: Material PVC Height: Above surface Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 108 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 265		
Fine Sand		4	21	10. Screen: Manufacturer's name _____ Pumpco Type PVC Dia. 5" Slot/gauze fine Length 40' Set between 68 ft. and 108 ft. ft. and _____ ft. Gravel pack <input checked="" type="checkbox"/> YES Size range of material #1 fine		
Fine sand with red clay streaks		21	48	11. Static water level: _____ mo./day/yr. 52 ft. below land surface Date 5-31-79		
Med. to Lar. Sand gravel		48	90	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.		
White clay with med. to lar. sand		90	105	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Clay		105	108	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ 18 Inches above grade		
WD-108'				15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> XX Yes _____ No		
				17. Pump: _____ Not installed Manufacturer's name Customers Windmill Model number _____ HP _____ Volts _____ Length of drop pipe 85 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ <input checked="" type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed _____ Date 11/26 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

38
 22
 17
 1/4
 1/4
 29
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5