


1 LOCATION OF WATER WELL		Fraction	Near center of north side		Section Number	Township Number		Range Number	
County: Ford		A.W. 1/4 A.E. 1/4 NW 1/4		18		T 28 S		R 23 EW	
Distance and direction from nearest town or city? 9 mi north-1/4 east of Bloom, Kansas					Street address of well if located within city?				
2 WATER WELL OWNER: Ralph Monger					Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box #: 2007 East Lane					Application Number: 32125				
City, State, ZIP Code: Dodge City, Kansas									
3 DEPTH OF COMPLETED WELL 247 ft. Bore Hole Diameter 28 in. to 247 ft. and in. to ft.									
Well Water to be used as:									
1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well									
2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)									
Well's static water level 113 ft. below land surface measured on 8-28 month 28 day 79 year									
Pump Test Data: Well water was 160 ft. after 3 hours pumping 900 gpm									
Est. Yield 1400 gpm: Well water was 180 ft. after 2 hours pumping 1100 gpm									
4 TYPE OF BLANK CASING USED:									
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped									
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded X									
Blank casing dia 16 in. to 107 ft. Dia in. to ft. Dia in. to ft.									
Casing height above land surface 12 in. weight 31.66 lbs./ft. Wall thickness or gauge No. 188									
TYPE OF SCREEN OR PERFORATION MATERIAL:									
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)									
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)									
Screen or Perforation Openings Are:									
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)									
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes									
7 Torch cut 10 Other (specify)									
Screen-Perforation Dia 16 in. to 247 ft. Dia in. to ft. Dia in. to ft.									
Screen-Perforated Intervals: From 107 ft. to 247 ft. From ft. to ft. From ft. to ft.									
Gravel Pack Intervals: From 10 ft. to 247 ft. From ft. to ft. From ft. to ft.									
5 GROUT MATERIAL:									
1 Neat cement 2 Cement grout 3 Bentonite 4 Other									
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well									
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well									
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)									
13 Watertight sewer lines none									
Direction from well How many feet Water Well Disinfected? Yes No X									
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample									
was submitted month day year Pump Installed? Yes X No									
If Yes: Pump Manufacturer's name Goulds Model No. 12JMC HP 125 Volts									
Depth of Pump Intake 230 ft. Pumps Capacity rated at 900 gal./min.									
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was 1 constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was									
completed on 12 month 13 day 79 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 190									
This Water Well Record was completed on 12-15 month 15 day 79 year under the business									
name of Ace-Hi International by (signature) Carl G. Neal									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:									
									
FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG									
0 3 Surface 219 222 Yellow clay									
3 68 Br clay & coleche 222 236 Med. snd & grv. & br rock									
68 96 Fine sand & 15 to 20% cl 236 239 Snd & grv & br. rock									
96 114 Fine to med. sand 239 251 Yellow & br clay									
114 122 Sndy cl & 40% fine snd 251 255 Gray shale									
122 152 Sand and gravel									
152 159 Coarse gravel									
159 170 Sndy cl & fine sand									
170- 176 Fine to med. sand									
176 201 Br cl & col & fine sand									
201 219 Fine to med. snd & cl									
ELEVATION: 201 219									
Depth(s) Groundwater Encountered 1. 113 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.