

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

D B C
SW NW SE

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County FORD	Township name Enterprise	Fraction SW NW SE	Section number 25	Town number 28 S	Range number 23 W
Distance and direction from nearest town or city:				3 Owner of well: BRADY HOOD		
Street address of well location if in city:				Address: FORD KANSAS		
Locate with "X" in section below:		Sketch map:		4 Well depth: 214 ft. Date of completion 9-3-75 Well diameter: 28 in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
2		Type and color of material		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Top Soil & clay		From 0 To 15		7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 24 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Clay		15 125		8 Screen: Manufacturer DOERR Type Punch Dia. 16 Slot/gauze 3/16 Length 60 Set between 174 ft. and 214 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 5/8		
Sand & Gravel		125 185		9 Static water level: 135 ft. below land surface Date 8-23-75		
Clay		185 195		10 Pumping level below land surfaces: 200 ft. after 3 hrs. pumping 900 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
Sand & Gravel		195 214		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
Shale		(9/4)		12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
BROCK 214'				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Clay mix <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From 0 ft. to 10 ft.		
135'				14 Nearest source of possible contamination: none ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
79' sat thick				15 Pump: 700 tanks <input type="checkbox"/> Not installed Manufacturer's name Morris Model number 7000 HP 100 Volts ____ Length of drop pipe 200 ft. capacity 700 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
214'				16 Remarks: elevation		
2209				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Brian Kelley Co & Son 217 Business name Box 56 Bucklin License No. ____ Address Box 56 Bucklin Signed Albert W. Brian Date 9-3-75 Authorized representative		
(use a second sheet if needed)						