

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>FORD</u>		Fraction <u>SW 1/4 SW 1/4 SW 1/4</u>		Section number <u>25</u>		Township number <u>N 28 S</u>		Range number <u>R 23 W</u>	
2. Distance and direction from nearest town or city: <u>3 N 2 W Kingsdown</u> Street address of well location if in city: <u>Kansas</u>				3. Owner of well: <u>Kenneth McCarthy</u> R.R. or street: <u>Kingsdown</u> City, state, zip code: <u>Kansas</u>					
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile				Sketch map:		6. Bore hole dia. <u>8 3/4</u> in. Completion date <u>9-2-77</u> Well depth <u>160</u> ft.			
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
				9. Casing: Material <u>PL</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>16</u> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <u>1.5</u> lbs./ft. Dia. <u>5 1/2</u> in. to <u>160</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>200</u>					
				5. Type and color of material				From	
<u>Top Soil</u>				<u>0</u>		<u>1</u>		11. Static water level: <u>23</u> ft. below land surface <u>9-2-77</u> mo./day/yr.	
<u>Tan Clay</u>				<u>1</u>		<u>58</u>		12. Pumping level below land surfaces: <u>23</u> ft. after <u>1</u> hrs. pumping <u>2 1/2</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>20</u> g.p.m.	
<u>Sandy Clay</u>				<u>58</u>		<u>66</u>		13. Water sample submitted: <u> </u> mo./day/yr. <u> </u> Yes <input checked="" type="checkbox"/> No <u> </u> Date <u> </u>	
<u>" " Hard</u>				<u>66</u>		<u>68</u>		14. Well head completion: <u>12</u> inches above grade <u> </u> Pitless adapter	
<u>Sandy Clay</u>				<u>68</u>		<u>106</u>		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <u> </u> Bentonite <u> </u> Concrete <u> </u> Depth: From <u>0</u> ft. to <u>14</u> ft.	
<u>Gravel (Fine To 3/4)</u>				<u>106</u>		<u>160</u>		16. Nearest source of possible contamination: <u>Lions Stock</u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <input checked="" type="checkbox"/> No	
(Use a second sheet if needed)								17. Pump: <u>Not installed</u> Manufacturer's name <u>Wendy</u> HP <u>1</u> Volts <u> </u> Model number <u> </u> Length of drop pipe <u>147</u> ft. capacity <u>22</u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CARL HAYSE WATER WELL SERV. 224 Business name <u>603 S. Maple, Greensburg, Kans.</u> License No. <u> </u> Address <u> </u> Signed <u>Carl Hayse</u> Date <u>9-2-77</u> Authorized representative					
Topography: <u> </u> Hill <u> </u> Slope <input checked="" type="checkbox"/> Upland <u> </u> Valley									