

WATER WELL RECORD (WWC-5)

Constructed

KOLAR DOC ID 1645434 WELL ID

Original Record Correction Change in Well Use

LOCATION OF WATER WELL

Latitude	37.598253	Longitude	-99.827055	Section	22	Township	28	Range	23	<input type="checkbox"/> E <input checked="" type="checkbox"/> W	Fraction	SW ¼ NE ¼ NW ¼
Datum	WGS84	Elevation	2428	County	Ford							

WATER WELL OWNER

Name	Cody Hawes
Business	
Address	12057 121 Rd Ford KS 67842
Well location	From Intersection 1212 Valley Rd 1/2 Mile south 1/4 mile east
<input type="checkbox"/> at owner's address	

WELL WATER USE

Domestic Livestock/Pasture

COMPLETION

Depth of completed well: 120 ft.

Depth(s) groundwater encountered:

(1) 58 ft.; (2) _____ ft.;

(3) _____ ft.; (4) dry well

Static water level in well: 58 ft.

measured below land surface on (mm/dd/yy): 05/17/2022

measured above land surface on (mm/dd/yy): _____

Estimated yield: 30 gpm

Water level was: _____ ft. after _____ hours pumping _____ gpm

Pump installed? Yes No

Water well disinfected? Yes No

Date disinfected (mm/dd/yy): 05/20/2022

Aquifer, if known: _____

NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: _____

Distance from well: _____ Direction from well: _____

Source description: _____

Source: _____

Distance from well: _____ Direction from well: _____

Source description: _____

No potential source of contamination within 100 feet.

CONSTRUCTION

Borehole interval: from 0 to 120 ft. Borehole diameter: 10 in.

Casing height above land surface: 18 in.

If casing height is less than 12 in. has a variance been approved?* Yes No

*variance not required for monitoring or environmental remediation wells

Casing type: ThermalPlastic

Blank casing interval: 0 ft. to 5 ft.

Blank casing diameter: 5 in.

Casing joints: Splines

Weight: _____ lbs/ft.

Wall thickness or gauge no.: SDR17

Blank casing interval: _____ ft. to _____ ft.

Blank casing diameter: _____ in.

Casing joints: _____

Weight: _____ lbs/ft.

Wall thickness or gauge no.: _____

Grout interval: 0 ft. to 40 ft.

Grout material: Bentonite

Grout interval: _____ ft. to _____ ft.

Grout material: _____

Screen / perforation material: PVC

Screen / perforation openings: Saw cut

Screen / perforation intervals:

From 80 ft. to 120 ft.

Slot size 32 unit millimet

From _____ ft. to _____ ft.

Slot size _____ unit

Gravel pack intervals:

Gravel pack not used: Gravel size _____ in

From 40 ft. to 120 ft.

Gravel pack not used: Gravel size _____ in

From _____ ft. to _____ ft.

LITHOLOGIC LOG

FROM	TO	LITHOLOGY INTERVALS
Attach	Attach	Attached

COMMENTS

CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed reconstructed pursuant to the stated water well contractor's license and was completed on 05/17/2022. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on _____ under the business name of Nash Water Well Service, LLC, Kansas Water Well Contractor's License No. 846 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: Trevor Nash.

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.

KANSAS DEPARTMENT OF HEALTH AND ENVIRONMENT

Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka KS 66612-1367 (785) 296-3565 | K.S.A. 82a-1212 | v2022c

Form	WWC5.2 - Water Well Record
Doc ID	1645434
Well Owner	Cody Hawes
Contractor	Nash Water Well Service, LLC

Lithology

	DB	
0	10	topsoil
10	20	clay, brown clay
20	33	, Tan Clay Fine Sand
33	40	, Fine Coarse Sand with small to large gravel & some small cobble
40	80	, Fine coarse sand with tan clay streaks
80	100	, Fine coarse sand small gravel
100	117	, Fine Coarse sand small to large gravel
117	122	, Tan clay tight
122	140	, Blue Clay Shale