

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

ACTE

1 Location of well:	County Ford	Township name Enterprise	Fraction NW SW NE	Section number 7	Town number 28	Range number 24
---------------------	-----------------------	------------------------------------	-----------------------------	----------------------------	--------------------------	---------------------------

Distance and direction from nearest town or city: **10 mi. Southeast of Dodge City, Kan.**


3 Owner of well: **E. K. Mace**

Street address of well location if in city:

Address: **Box 13, Spearville, Kansas**

Locate with "X" in section below:

Sketch map:



4 Well depth: **205** ft. Date of completion **1-8-75**
Well diameter **28** in.

5 Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

6 Use: Domestic Public supply Industry
 Irrigation Air conditioning Commercial
 Test well

7 Casing: Material _____ Height: above/below _____
Threaded Welded Surface **14** in.
Diam. **16** in. Weight _____ lbs./ft. _____
16 in. to **205** ft. depth Drive shoe? Yes No
_____ in. to _____ ft. depth

2	Type and color of material	From	To
	Surface	0-3	
	Brown clay	3	20
	Sandy clay	20	40
	Down clay	40	122
	Fine sand with 15% clay mixed	122	140
	A-1 sand and gravel	140	200
	Fine sand with 20% clay mixed	200	207
	Sandy clay	207	216
	Caleche clay	216	240
	Yellow clay	240	247
	Yellow and brown clay	247	274
	Shale	274	280
	ROCK 240'		
	148		
	92' sat thick		
	MOG		

8 Screen: **Free-flo (W.A. Brown)**
Manufacturer _____
Type **10%** Dia. **16**
Slot/gauze **1/8** Length _____
Set between **135** ft. and **205** ft. #1 blend to
Fittings: _____
Gravel pack Yes No Size range of material **3/8**

9 Static water level: **148** ft. below land surface Date **1-8-75**

10 Pumping level below land surfaces:
175 ft. after **2** hrs. pumping **1212** g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield **1500** g.p.m.

11 Water sample submitted:
 Yes No Date _____

12 Well head completion:
 Pitless adapter Inches above grade

13 Well grouted? Yes No
 Neat cement Bentonite _____
Depth: From _____ ft. to _____ ft.

14 Nearest source of possible contamination:
ft. _____ Direction **NA** Type _____
Well disinfected upon completion? Yes No

15 Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

16 Remarks: elevation

Topography:

- Hill
 Slope
 Upland
 Valley

TOPO 2602
240'
240'
240'

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Ace-Hi Drilling Co.-190A
Business name _____ License No. _____
Address **Box 1442, Dodge City, Ks**
Signed **Carl C. Little** Date **1-29-75**
Authorized representative

Ford Co.

3-25-75

To:

Kansas Dept. of Health & Environment

Water Well Contractors

Topeka, Kansas

This is to inform you that the following pump was installed for E. K. Mace in the well drilled in section 7, township 28, range 24-W. Well was drilled 1-8-75, pump set 3-21-75

Goulds pump with 190' of drop pipe-80 HP and designed for 1200 GPM open flo.

Carl C. Tittel
Ace-Hi Drilling Co
License #190

