


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NW 1/4 NW 1/4 NE 1/4	Section number 12	Township number T 28 S	Range number R 24 W
2. Distance and direction from nearest town or city: 8 mi south & 6 1/2 mi east of Dodge City				3. Owner of well: M. A. Conrad R.R. or street: RFD 3 City, state, zip code: Dodge City, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 364 ft. 2-25-78		
				7. Cable tool _____ Rotary _____ Driven _____ Dug _____ Hollow rod _____ Jetted _____ Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: _____ Domestic _____ Public supply _____ Industry <input checked="" type="checkbox"/> Irrigation _____ Air conditioning _____ Stock _____ Lawn _____ Oil field water _____ Other		
Surface		0	3	9. Casing: Material <u>metal</u> Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface _____ 10 in. RMP _____ PVC _____ Weight 31.66 lbs./ft. Dia. 16 in. to 364 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 188		
Brown clay		3	75	10. Screen: Manufacturer's name _____ W. A. Brown		
Fine sand		75	100	Type 10% Free-flow Dia. 16 Slot/gauze 1/8 Length 260 Set between 104 ft. and 364 ft. _____ ft. and _____ ft.		
Fine sand and clay mixed		100	110	Gravel pack? yes Size range of material 1/2 down		
Good fine to med. sand and gravel		110	140	11. Static water level: _____ mo./day/yr. 108 ft. below land surface Date 10-24-77		
Gray clay		140	152	12. Pumping level below land surfaces: NA not pumped _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Gray clay & fine sand		152	160	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
Green & Gray clay with coleche		160	182	14. Well head completion: _____ Pitless adapter <input checked="" type="checkbox"/> Inches above grade _____		
50% fine sand-50% clay		182	197	15. Well grouted? yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete _____ Depth: From 0 ft. to 10 ft.		
Coleche brown rock and clay		197	220	16. Nearest source of possible contamination: _____ ft. 600 Direction NE Type septic Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No _____		
Good fine to med. sand and gravel		220	247	17. Pump: _____ Not installed Manufacturer's name Western Land Roller Model number 12C-H HP 125 Volts _____ Length of drop pipe 250 ft. capacity 800 g.p.m. Type: _____ _____ Submersible _____ <input checked="" type="checkbox"/> Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
Sand and clay		247	251			
Brown coleche clay		251	303			
Good fine to 1/2 med. sand and fine gravel		303	328			
Clay and sandy clay		328	336			
Fine sand with 25% clay		336	345			
Half med. sand and fine gravel		345	360			
Yellow clay		360	370			
Blue shale		370	375			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name _____ License No. _____ Address Dodge City, Kansas Signed Carl G. J. J. Date 2-28-78 Authorized representative		
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5