

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY


WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1. Location of well:	County Ford	Township name Enterprise	Fraction SE 1/4 of NE 1/4	Section number s-29	Town number T-28-S	Range number R-24-W
----------------------	-----------------------	------------------------------------	-------------------------------------	-------------------------------	------------------------------	-------------------------------

Distance and direction from nearest town or city: 1 1/2 mi. south and 2 1/2 mi east of Dodge Street address of well location if in city:	3 Owner of well: Joe F. Wilcoxon 1701 Sundown Drive Address: Colo. Spgs., Colo
---	---

Locate with "X" in section below: 	Sketch map:	4 Well depth: 202 ft. Date of completion 12-24-75 Well diameter 28" in.
--	-------------	---

2	Type and color of material	From	To	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>
	Surface	0	3	7 Casing: Material Metal Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. Diam. 16 in. to 102 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 30 lbs./ft. 1
	Brown and caleche clay	3	71	8 Screen: Manufacturer W. A. Brown Inc. Type Free-flo Dia. 16" Slot/gauze 1/8 Length 100' Set between 102 ft. and 202 ft.
	Fine sand with 30% clay mixed	71	82	Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material GMA
	Brown caleche clay	82	101	9 Static water level: NA 126 ft. below land surface Date 2-25-77
	Med. sand and gravel	101	119	10 Pumping level below land surfaces: 93 ft. after 2 hrs. pumping 900 g.p.m. 100 ft. after 2 hrs. pumping 1400 g.p.m. Estimated maximum yield 2000 g.p.m.
	Brown caleche clay	119	125	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
	A-1 fine to med. sand and gravel	125	196	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
	Caleche clay	196	210	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
				14 Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 10JMC HP 90 Volts Length of drop pipe 180 ft. capacity 500 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
	(use a second sheet if needed)			

16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International Inc. Business name License No. Address Dodge City, Kansas Signed Paul C. Anttil Date 1-20-76 Authorized representative
--	---