

1 LOCATION OF WATER WELL		Fraction	Section Number		Township Number	Range Number
County: Ford		NW 1/4 NE 1/4 NE 1/4	31		T 28 S	R 24 EW
Distance and direction from nearest town or city? Dodge City 14S, 3E, 2N, 1W			Street address of well if located within city?			
2 WATER WELL OWNER:		Board of Agriculture, Division of Water Resources				
RR#, St. Address, Box # :		Application Number: 30,842				
City, State, ZIP Code :		Mineola, Kansas 67865				
3 DEPTH OF COMPLETED WELL 352 ft. Bore Hole Diameter 28 in. to 352 ft. and in. to ft.						
Well Water to be used as:						
1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well						
2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)						
Well's static water level 99 ft. below land surface measured on August month 14 day 1981 year						
Pump Test Data : Well water was 118 ft. after 1/4 hours pumping 929 gpm						
Est. Yield 2,000 gpm: Well water was 145 ft. after 1 hours pumping 2183 gpm						
4 TYPE OF BLANK CASING USED:						
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped						
2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded X						
Blank casing dia 16 in. to 162 ft. Dia in. to ft. Dia in. to ft.						
Casing height above land surface 12 in., weight 37 lbs./ft. Wall thickness or gauge No 219						
TYPE OF SCREEN OR PERFORATION MATERIAL:						
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement						
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)						
Screen or Perforation Openings Are:						
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)						
2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes						
3 Torch cut 10 Other (specify) Bridge						
Screen-Perforation Dia 16 in. to 352 ft. Dia in. to ft. Dia in. to ft.						
Screen-Perforated Intervals: From 162 ft. to 352 ft. From ft. to ft.						
Gravel Pack Intervals: From 10 ft. to 352 ft. From ft. to ft.						
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other						
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.						
What is the nearest source of possible contamination:						
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well						
2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well						
3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)						
13 Watertight sewer lines Unknown						
Direction from well How many feet ? Water Well Disinfected? Yes X No						
Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample						
was submitted month day year Pump Installed? Yes No X						
If Yes: Pump Manufacturer's name Model No. HP Volts						
Depth of Pump Intake ft. Pumps Capacity rated at gal./min.						
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other						
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was						
completed on August month 31 day 1981 year						
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 102						
This Water Well Record was completed on September month 25 day 1981 year under the business						
name of Layne-Western Company, Inc. by (signature) <i>[Signature]</i>						
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG		FROM TO LITHOLOGIC LOG		
		0 2 Surface		281 290 Sand & gravel with little clay		
		2 40 Clay with little caliche				
		40 101 Sandy clay		290 335 Sandy clay		
		101 144 Sand & gravel with little clay		335 352 Sand streaks & clay streaks		
		144 161 Sandy clay & sand streaks		352 364 Broken rock		
		161 192 Loose sand & gravel		364 376 Caliche		
		192 230 Sandy clay		376 380 Clay streaks & sand streaks		
		230 252 Sand & gravel with little clay		380 400 Hard sandy clay with little shale		
		252 281 Sandy clay				
		ELEVATION:				
Depth(s) Groundwater Encountered 1. 101 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)						
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.						