


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County FORD	Township name E CONCORD	Fraction NE 1/4	Section number 23	Town number 28	Range number 25
Distance and direction from nearest town or city: FROM DODGE CITY KAN 9 1/2 SOUTH ON 283 3/4 WEST				3 Owner of well: DWIGHT WINGER Address: RFD 1 DODGE CITY KAN		
Locate with "X" in section below: N		Sketch map:		4 Well depth: 202 ft. Date of completion _____ Well diameter 28 in.		
		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____		
		7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. Diam. _____ Weight _____ lbs./ft. _____ 16 in. to 202 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth				
2 Type and color of material				From	To	8 Screen: Manufacturer WA BROWN Type BRIDGE Dia. 16 Slot/gauze 8 Length _____ Set between _____ ft. and _____ ft. _____ Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 down
SURFACE				0	3	9 Static water level: 95 ft. below land surface Date 9-5 75
CLAY & CALICHE				3	68	10 Pumping level below land surfaces: 120 ft. after 1 hrs. pumping 1400 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1900 g.p.m.
SAND & GRAVEL				68	74	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
CLAY				74	76	12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ inches above grade
SAND & GRAVEL				76	95	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> CEMENT Depth: From 0 ft. to 10 ft.
HARD LAYER CLAY				95	101	14 Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
SAND				101	110	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name WESTERN LAND DRILL Model number _____ HP _____ Volts _____ Length of drop pipe 150 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
CALICHE & CLAY				110	114	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JO JOHNSON DRILL 183 Business name _____ License No. _____ Address DODGE CITY KAN Signed JO JOHNSON Date 10-31-75 Authorized representative
SAND & GRAVEL				114	200	
CLAY				200	205	
(use a second sheet if needed)						
16 Remarks: elevation						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

28
25 W
23
CWA/2-75
NE