


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County FORD	Township name CONCORD	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 25	Town number 28 S	Range number 24 W
Distance and direction from nearest town or city: 20 South Dodge City				3 Owner of well: John Perrier		
Street address of well location if in city:				Address: Rt 1, Dodge City KS		
Locate with "X" in section below:		Sketch map:		4 Well depth: 210 ft. Date of completion 19 Nov 75 Well diameter 8 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material PVC Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. blue Weight 25 lbs./ft. 5 in. to 210 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer Jess + Lowell Type PVC Dia. 5 5/8 gauze 150 length 3 Set between 150 ft. and 210 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 18		
2		Type and color of material		From	To	9 Static water level: 170 ft. below land surface Date 19 Nov 75
		Soil		0	2	10 Pumping level below land surfaces: N/A _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
		CLAY		2	64	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		Rock		64	92	12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade
		CLAY		92	131	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 20 ft. to 0 ft.
		GRAVEL		131	139	14 Nearest source of possible contamination: ft 1500 Direction SW Type Feed yard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
		Rock		139	153	15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Reo Model number 140108 P HP 1 1/2 Volts 200 Length of drop pipe 189 ft. capacity 1800 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
		GRAVEL & CLAY		153	210	17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CRAGG DRILLING 111 Business name License No. Address Rt 1, Dodge City KS Signed Steve Deery Date 20 Nov 75 Authorized representative
16 Remarks: elevation Please send more forms						
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

28 26 W 25 NE SE SW