

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 5	Township number T 28 S R 28	Range number 28 XEW
2. Distance and direction from nearest town or city: 3 1/2 n., 2 3/4 E.	3. Owner of well: Bob Hartnett R.R. or street: City, state, zip code: Montezuma, Kansas 67867				
4. Locate with "X" in section below: 	Sketch map:				
5. Type and color of material	From	To	6. Bore hole dia. 9 7/8 in. Completion date July 10, 1979 Well depth 266 ft.		
Top Soil	0	7	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Clay	7	38	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine to medium sand	38	140	9. Casing: Material PVC Height: Above XX in. Threaded <input type="checkbox"/> Welded X Surface 12 in. RMP <input type="checkbox"/> PVC X Weight 2.8 lbs./ft. Dia. 5 in. to 266 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 265		
Sandy Clay	140	151	10. Screen: Manufacturer's name Pump Co Type PVC Dia. 5" Slot/gauze 1/8" Length 60' Set between 206 ft. and 266 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes size range of material #1 fine		
Med. to Lar. Sand	151	262	11. Static water level: 152 ft. below land surface Date 7-6-79		
Yellow Clay - tight	262	268	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.		
WD-266!			13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes XX No Date <input type="checkbox"/>		
			14. Well head completion: XX Pitless adapter <input type="checkbox"/> Inches above grade		
			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. 55 Direction N Type sewer Well disinfected upon completion? X Yes <input type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Aermotor Model number SD19 HP 2 Volts 220 Length of drop pipe 231 ft. capacity 20 g.p.m. Type: XX Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope XX Upland <input type="checkbox"/> Valley		
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Meade Kansas 67864 Signed <input type="checkbox"/> Authorised representative Date 11-26-79		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5