


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 5	Township number T 28 S	Range number R 28 E/W	
2. Distance and direction from nearest town or city: 3 N. & 1 1/2 E. of Montezuma Street address of well location if in city:	3. Owner of well: Bernard Martin R.R. or street: Dodge City, KS 67801 City, state, zip code:					
4. Locate with "X" in section below: 	Sketch map:					
5. Type and color of material See attachment	From	To	6. Bore hole dia. 26 in. Completion date 11-11-76 Well depth 242 ft.			
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 242 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250			
			10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16" Slot/gauze .125 Length 50' Set between 150 ft. and 200 ft. ft. and ft. Gravel pack? Yes Size range of material 1/4 x 1/8			
			11. Static water level: mo./day/yr. 136 ft. below land surface Date			
			12. Pumping level below land surfaces: 178 ft. after hrs. pumping 1435 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: Pitless adapter 12 inches above grade			
			15. Well grouted? Yes With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: None ft. Direction Type observed Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilg. & Supply 145 Business name <input type="checkbox"/> License No. Address Box 639, Garden City, KS Signed <input type="checkbox"/> Date 12-7 Authorized representative			
18. Elevation: Flat	19. Remarks: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Bernard Martin DATE 11-3-76
STREET ADDRESS TEST # 7 E. Log
CITY & STATE Dodge City, KS DRILLER Lee
COUNTY Gray QUARTER NW SECTION 5 TOWNSHIP 28 RANGE 28
LOCATION 258' W. of Test #3

WELL LOCATION

%	DRILLED FOOTAGE			Static Water Level	
	From	Pay	To	Description of Strata	Proposed Well Depth
	0		3	Top soil	
	3		17	Brown clay, fine sand st.	
	17		20	Fine to few med. sand	
	20		38	Brown clay, sand st.	
	38		72	Sand fine to med., few clay st.	
	72		130	Brown clay, ledges and sand st., few caliche st.	
65	130	12	142	Sand fine med. coarse, small gravel, and some med., very few clay st., used water	
	142		150	Brown clay, ledges, few sand st.	
60	150	30	180	Sand fine med. coarse, small gravel, few med., very few clay st.	
65	180	14	194	Sand fine med. coarse, small, med. gravel, few large, few cemented ledges, a little rough in places, very few clay st., used water, few brown gravel	
	194		200	White and tan clay, ledges, few sand st.	
	200		209	Brown clay, a lot of sand st.	
20	209	6	215	Sand fine med., clay st.	
	215		223	Brown clay, few sand st.	
25	223	10	233	Sand fine med. and clay	
	233		244	Brown clay, sand st.	
	244		250	Very hard lime rock and soapstone	
	72			TOTAL DEPTH OF WELL 242'	
				Set up west	
				Pit on north	

GARDEN CITY, KS
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.

SUBLETTE, KS

PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
TEST HOLES ***** IRRIGATION AND INDUSTRIAL WELLS ***** STOCK WELLS

TEST HOLES*****IRRIGATION AND INDUSTRIAL WELLS*****STOCK WELLS