

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 7	Township number T 28 S R 23 E NW	Range number 23
2. Distance and direction from nearest town or city: 1 east, 1 3/4 north of John Deere at Street address of well location if in city: Montezuma			3. Owner of well: John Paul Unruh R.R. or street: Box 273 City, state, zip code: Montezuma, Ks. 67867		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 5-13-77 Well depth 212 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 213 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/groove <input type="checkbox"/> Length 20 ft. Set between 130 ft. and 200 ft. Perf: 160-180 ft. and 200-212 ft. Gravel pack? yes Size range of material 1/2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 126 ft. below land surface Date 3-30-77		
			12. Pumping level below land surfaces: 151 ft. after 2 hrs. pumping 700 g.p.m. 169 ft. after 4 hrs. pumping 1125 g.p.m. Estimated maximum yield 1125 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 10 JHC HP 80 Volts <input type="checkbox"/> Length of drop pipe 200 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation:			19. Remarks:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			(Use a second sheet if needed)		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A Garden City, Ks. Signed <i>[Signature]</i> Date 5-30-77 Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

28 280 - 7 NE NW NE
T R Sec 1/4 1/4 1/4

Professional

MINTER-WILSON DRILLING CO.
INCORPORATED

WILLIAM
MINTER
WILSON
Drilling

Phone 178-8769 P.O. Box A GARDEN CITY, KANSAS 66503

JOHN CRONIN
GRAY COUNTY

Location: NE 7-28-26 from north east corner go south
7/10 next to the road ditch

Static Water Level- 130'

Test #3

0	2	Top soil
2	6	Brown clay
6	83	Brown sandy clay
83	97	Med. sand to med. coarse gravel loose
97	121	Brown sandy clay
121	156	Med. sand to med. gravel
156	166	Brown sandy clay
166	188	Fine to med. sand and gravel loose
188	203	Fine to med. sand and gravel
203	211	Brown sandy clay 10% gravel streak
211	224	Yellow clay and rock hard pull down
224	227	Shale

T... 212