


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Montezuma	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 6	Town number 28	Range number 29 W
Distance and direction from nearest town or city: 3 Mile North & $4\frac{1}{2}$ West of Montezuma			3 Owner of well: Alvin B. Koehn Route 2 Montezuma, Kansas			
Street address of well location if in city:						
Locate with "X" in section below:		Sketch map:				
						
		4 Well depth: <u>352</u> ft. Date of completion <u>11-10-75</u> Well diameter <u>10</u> in.				
		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary				
		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well				
		7 Casing: Material <u>Steel</u> Height: above <u>100</u> ft. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. Weight <u>100</u> lbs./ft. <u>16</u> in. to <u>352</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>100</u> in. to <u>352</u> ft. depth				
		8 Screen: <u>W. A. Brown Ent.</u> Manufacturer <u>Bridge</u> Dia. <u>16"</u> Type <u>Bridge</u> Dia. <u>16"</u> Slot/gauze <u>Slat</u> Length <u>2"</u> Set between <u>272</u> ft. and <u>352</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>5/8</u>				
		9 Static water level: <u>120</u> ft. below land surface Date <u>11-10-75</u>				
		10 Pumping level below land surfaces: <u>160</u> ft. after <u>5</u> hrs. pumping <u>1200</u> g.p.m. <u>160</u> ft. after <u>5</u> hrs. pumping <u>1200</u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.				
		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____				
		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade				
		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.				
		14 Nearest source of possible contamination: ft. _____ Direction _____ Type <u>None</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
		15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Layne</u> Model number <u>1975 HP 100 Volts</u> Length of drop pipe <u>240</u> ft. capacity <u>1200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
		16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				
		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Dunham Drilling 223</u> Business name <u>Copeland, Kansas</u> License No. _____ Address _____ Signed <u>John Dunham</u> Date <u>4-5-76</u> Authorized representative <u>John Dunham</u> Date <u>4-5-76</u>				

Forward the white, blue and pink copies to the Kansas State Dept. of Health.

Form WWC-5