

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction CENTER OF $\frac{1}{4}$ SW 1/4 1/4 1/4	Section number 19	Township number T 28 S	Range number R 29 NW			
2. Distance and direction from nearest town or city: of Montezuma feeders, 2 north, $\frac{1}{4}$ east, $\frac{1}{4}$ South	3. Owner of well: Lincoln L. Koehn R.R. or street: Copeland, Ks 67837 City, state, zip code:							
4. Locate with "X" in section below:	Sketch map: 							
5. Type and color of material	From	To	6. Bore hole dia. 26 in. Completion date 3-31-76 Well depth 288 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 289 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/> 10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16 in. Slot/gauze 100 Length 20' Set between 210 ft. and 220 ft. Perf. 150-210 ft. and 230-258 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1" Down 11. Static water level: mo./day/yr. 111 ft. below land surface Date 3-23-76 12. Pumping level below land surfaces: 210 ft. after 3 hrs. pumping 625 (some air) <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 600 g.p.m. 13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> 14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input checked="" type="checkbox"/> Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> 17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US pumps Model number 12JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 210 ft. capacity 600 g.p.m. Type: <input checked="" type="checkbox"/> <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: (Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name P.O. Box A Garden City KS Address <input type="checkbox"/> Signed <input type="checkbox"/> Date 7-16-77 Authorized representative <input type="checkbox"/> 28 29 1/4 Sec 1/4 CSC		

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

LINCOLN L. KOEHN

GRAY COUNTY

1-30-76

Location Sw 19-28-29
At Center Of Quarter

Static Water Level 140'

Test #5

0	1	Top Soil
1	3	Brown Clay
3	92	Brown Sandy Clay
92	112	Gray & White Clay
112	125	Brown Sandy Clay
125	154	Fine To Med. Sand & Gravel (Loose)
154	185	Brown & White Sandy Clay
185	200	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
200	215	Fine To Med. Sand & Gravel (Loose)
215	230	Fine To Med. Sand & Gravel, Streaks Of Clay (10%)
230	248	Fine Sand, Streaks Of Clay (20%) Tight
248	260	Brown Sandy Clay
260	275	Fine To Med. Sand, Streaks of Clay (30%) Tight
275	281	Fine To Med. Sand & Gravel, Streaks Of Clay (10%) Loose
281	288	Fine Sand, Streaks Of Clay (20%) Tight
288	302	Brown, Gray, yellow clay
302	305	Shale