

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 NW 1/4 NW 1/4	Section number 20	Township number T 28 S R 29	Range number W
2. Distance and direction from nearest town or city:	Street address of well location if in city:		3. Owner of well: R.R. or street: City, state, zip code:	Victor Smith XXXXXX Montezuma, Kansas 67867	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia 9 7/8 in. Completion date 9-16-76 Well depth 410 ft.		
5. Type and color of material	From	To	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top soil	0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy tan clay	3	42	9. Casing: Material <input type="checkbox"/> PVC <input checked="" type="checkbox"/> PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 291 lbs./ft. Dia. 5 in. to 410 ft. Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 265		
Tan clay with sand streaks	42	138	10. Screen: Manufacturer's name Jess & Lowell Type <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Dia. 5" Slot/gauze 1/8" Length 100 fine Set between 220 ft. and 410 ft. ft. and 410 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 3/16"		
Med. to lar. sand with clay streaks	138	185	11. Static water level: 233 1/2 ft. below land surface Date 9/11/76		
Yellow clay & gray clay	185	220	12. Pumping level below land surfaces: 270 ft. after 8 hrs. pumping 22 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
Med. to lar. sand with clay streaks	220	243	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Yellow clay	243	310	14. Well head completion: <input checked="" type="checkbox"/> Pitless <input type="checkbox"/> unit <input type="checkbox"/> Inches above grade		
Med. to lar. sand with clay streaks	310	410	15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.		
(Use a second sheet if needed)			16. Nearest source of possible contamination: ft. 40 Direction south Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> east Yes <input type="checkbox"/> No		
18. Elevation:	19. Remarks:		17. Pump: Manufacturer's name Aermotor Model number SD19 HP 3 Volts 220 Length of drop pipe 315 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name <input type="checkbox"/> Meade, Kansas 67864 License No. Address <input type="checkbox"/> Signed John Friesen Date 9-28-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5