


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 21	Township number T 28	Range number S 29 E/W
2. Distance and direction from nearest town or city: 1/2 south, 1/2 west of Montezuma, Ks. Street address of well location if in city:	3. Owner of well: R.R. or street: City, state, zip code: Verle Soice Montezuma, Ks.				
4. Locate with "X" in section below: 	Sketch map:				
6. Bore hole dia. 26 in. Completion date 4-25-75 Well depth 260 ft.					
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material <input checked="" type="checkbox"/> steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia 16 in. to 261 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>					
10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type <input checked="" type="checkbox"/> Galv. Dia. 16" Slot/gauze 80 Length 20' Set between 230 ft. and 250 ft. Perf: 140-230 ft. and 250-260 ft. Gravel pack? Yes Size range of material 1/2" down					
11. Static water level: mo./day/yr. 110 ft. below land surface Date					
12. Pumping level below land surfaces: 216 ft. after 2 hrs. pumping 308 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 300 g.p.m.					
13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <i>May not yield enough for pump.</i>				
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address <input type="checkbox"/> P.O. 493 Garden City, Ks. Signed <input type="checkbox"/> Date 11-1 Authorized representative <input type="checkbox"/>					

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Gray County

Verle Soice

February 7, 1975

Location: N.W. Corner of $\frac{1}{4}$

Test # 4

0 2 Top Soil

2 110 Brown Clay, Lost circulation 95-110

110 123 Brown Sandy Clay, streaks of gravel 35% (Loose)

123 140 Fine to Medium Sand & Gravel 20% Clay (Loose)

140 155 Fine to Medium Sand & Gravel 30% Clay (Loose)

155 173 Fine to Medium Sand & Gravel 10% Clay (Loose)

173 200 Fine to Medium Sand & Gravel (Loose)

200 260 Fine to Medium Sand & Gravel 10% Clay (Loose)

260 269 Brown, Gray & Yellow Clay (tight)

269 275 Shale (Hard)