


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grey	Fraction N $\frac{1}{4}$ NW $\frac{1}{4}$ NE $\frac{1}{4}$	Section number 32	Township number T 28	Range number S R 29	E.W. $\frac{1}{4}$
<input checked="" type="checkbox"/> Distance and direction from nearest town or city: 3 1/2 W, 3 1/4 S, 1/4 W of Montezuma Street address of well location if in city:			3. Owner of well: David Toews R.R. or street: City, state, zip code: Montezuma, Kansas 67867			
4. Locate with "X" in section below: 						
5. Type and color of material						
Top Soil		From 0	To 5	6. Bore hole dia. 7 7/8 in. Completion date 9-13-78 Well depth 207 ft.		
Clay		5	43	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Fine Sand		43	55	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy Clay		55	102	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded X Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 207 ft. depth <input checked="" type="checkbox"/> Wall Thickness: 1/8 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> gage No. 265		
Med. to Lar. Sand		102	170	10. Screen: Manufacturer's name Pump Co Type PVC Dia. 5" Slot/gauze fine/1/8" Length 60' Set between 147 ft. and 207 ft. ft. and 207 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #1 Fine		
Sandy Clay		170	208	11. Static water level: 120 ft. below land surface Date 9-8-78 mo./day/yr.		
12. Pumping level below land surfaces: ft. after _____ hrs. pumping _____ g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.						
13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date _____ mo./day/yr.						
14. Well head completion: X Pitless <input type="checkbox"/> unit _____ Inches above grade						
15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.						
16. Nearest source of possible contamination: ft. 10 Direction # South Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
17. Pump: Aermotor Not installed Manufacturer's name Customer's old pump Model number SD12 HP 3/4 Volts 220 Length of drop pipe 151 ft. capacity 10 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						
19. Remarks: (Use a second sheet if needed)						
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name Meade, Kansas 67864 License No. Address 1/4 NE 1/4 1/4 NW 1/4 Signed John Friesen Date 11-21-78 Authorized representative						