


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray County	Fraction 1/4 C 1/4 SW 1/4	Section number 1	Township number T 28 S R 30 E W	Range number
2. Distance and direction from nearest town or city 5 East, 2 South, 1 East and 1 North of Channel 13 Street address of well location if in city:			3. Owner of well: Eldon Amend R.R. or street: 813 Sunrise City, state, zip code: Derby, KS 67037		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 10-10-77 Well depth 330 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 330 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
					10. Screen: Manufacturer's name Johnson Type Johnson Galv. Di. 100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between 0-160 Plain and 160-190 Perf. 190-210 Screen and 210-330 Perf. ft. Gravel pack? yes Size range of material 1/2 to 5/8
					11. Static water level: <input type="checkbox"/> mo./day/yr. 126 ft. below land surface Date 9-16-77
					12. Pumping level below land surfaces: 160 ft. after 2 hrs. pumping 1100 g.p.m. 171 ft. after 4 hrs. pumping 1650 g.p.m. Estimated maximum yield 1650 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 6 stg. 12" Bowl Model number Electric Motor 125HP Length of drop pipe 200 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. 6784 Address Box A, Garden City, KS Signed [Signature] Date 1-1977 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

28 300 1 1/4 C SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

ELDON AMEND
GRAY COUNTY
9-1-77

Location: 105' north of test 1 SW 1-28-30
Static Water Level: 130'
Test: 3

0	5	Top soil
5	19	Brown clay
19	32	Brown sandy clay
32	57	Fine sand, 20% clay
57	93	Brown sandy clay
93	100	Fine to medium sand and gravel (tight)
100	127	Fine to medium sand and gravel (loose)
127	143	Fine to medium sand and gravel, hard pull down
143	154	Brown sandy clay
154	175	Fine to medium sand and gravel
175	197	Fine to medium sand and gravel (tight) 10% clay
197	212	Fine to medium sand and gravel (loose)
212	235	Brown sandy clay
235	258	Brown sandy clay mixed with white rock (no good)
258	314	Brown sandy clay
314	328	Fine sand, small yellow rock, brown rock mixed, 15% clay
328	347	Yellow clay
347	350	Shale

TD 330
20' screen