


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name N.W.N.W.N.E.	Fraction	Section number 3	Town number T 28 S	Range number R 30 W
Distance and direction from nearest town or city: $7\frac{1}{4}$ N. $2\frac{1}{2}$ E. of Copeland Kansas 67837			3 Owner of well: Ernest Fry Copeland, Kansas 67837 Address: This is the only address given.			
Locate with "X" in section below:  Sketch map:						
4 Well depth: 280 ft. Date of completion 4/7/75 Well diameter 9 in.						
5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary						
6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well						
7 Casing: Material RMP Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. 320 lb. Weight 1 5 in. to 240 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth						
8 Screen: Manufacturer Sunflower Type RMP Dia 5" Set/gauze 1/16 Length 40 Set between 240 ft. and 280 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 7/8						
9 Static water level: 162 ft. below land surface Date 4/7/75						
10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.						
11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date						
12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade						
13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 15 ft.						
14 Nearest source of possible contamination: Septic ft. 60 Direction North Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No						
15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T. & W. Waterwell Serv. 142 Business name Box 816 Liberal, KS License No. Address Signed <i>George J. ...</i> Date 4/7/75 Authorized representative						
(use a second sheet if needed)						
16 Remarks: elevation Well is to be completed by Dunham Drilling Company Copeland, Kansas 67837						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						