


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$	Section number 10	Township number T 28	S R 30	Range number E/W
2. Distance and direction from nearest town or city: 3 mi E 5 N of Copeland	3. Owner of well: Roger Koehn					
Street address of well location if in city: Copeland, KS 67837						
4. Locate with "X" in section below: N		Sketch map:			6. Bore hole dia. 9 in. Completion date 4/25/78 Well depth 260 ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material PHS Height: Above or below Threaded <input type="checkbox"/> Welded 91 Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight lbs./ft. Dia. 5 in. to 200 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.258	
5. Type and color of material		From 0	To 140	10. Screen: Manufacturer's name J+L Type PVC Dia. 5" Slot/gauze 1/16 Length 60 Set between 200 ft. and 260 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 18		
overburden				11. Static water level: 140 ft. below land surface Date 4/25/78 mo./day/yr.		
Sand + Gravel		140	260	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 80 g.p.m.		
				13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: Pitless adapter 14 Inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 400 Direction SE Type Septic Well disinfected upon completion? Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	
					19. Remarks: Well to be completed by: Dunham Drilling Copeland, KS 67837	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+L Water Well 142 Business name <input type="checkbox"/> Address Box 818 Liberal, KS License No. <input type="checkbox"/> Signed <input type="checkbox"/> Authorized representative Date 4/25/78 Authorized representative	