


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location

Location of well:	County	Fraction	Section number	Township number	Range number
X	Gray	NE 1/4 SE 1/4 SE 1/4	13	T 28	S R 20 E 0
4. Distance and direction from nearest town or city: 4 East 4 South of Copeland, KS.			3. Owner of well: R.R. or street: C. N. Koehn		
Street address of well location if in city:			City, state, zip code: Montezuma, KS 67867		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 9 in. Completion date 8/9/77 Well depth 200 ft.		
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded 31 Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 100 lbs./ft. Dia. 5 in. to 140 ft. depth Wall Thickness: inches or Dia. 5 in. to ft. depth gage No. 0.258		
5. Type and color of material			From	To	10. Screen: Manufacturer's name J+L Type PVC Dia. 5'' Slot/gauze 1/16 Length 60 Set between 140 ft. and 200 ft. Gravel pack? Yes Size range of material 1/8
Overburden			0	115	
Fine Sand + gravel			115	140	
Sand + gravel			140	200	
					11. Static water level: 115 ft. below land surface Date 8/9/77
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 30 g.p.m.
					13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion: Pitless adapter 14 inches above grade
					15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 500 Direction South Type Septic Well disinfected upon completion? Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley
Well to be completed by: Dunham Drilling Copeland KS			19. Remarks: T+L Water Well 142 Business name Box 816 Liberal KS License No. Address Signed <input type="checkbox"/> Authorized representative Date 8/9/77		
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.					