

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	SW 1/4 NE 1/4 SW 1/4	23	T 28	S R 30 E/W
2. Distance and direction from nearest town or city:	South of Charleston to the 22 mile road, 3 south, Street address of well location if in city: 1 east, 1/2 south, 1/2 west		3. Owner of well: R.R. or street: City, state, zip code:	Walter Redger Montezuma, Ks. 67867	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 26 in. Completion date 6-30-76 Well depth 350 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input checked="" type="checkbox"/> steel Height: Above <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 351 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Type <input checked="" type="checkbox"/> Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 190-210 and <input type="checkbox"/> ft. Perf: 140-190 ft. and 280-350 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 123 ft. below land surface Date 6-28-76		
			12. Pumping level below land surfaces: 149 ft. after 3 hrs. pumping 2300 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 2300 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: <input type="checkbox"/> N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Manufacturer's name <input type="checkbox"/> Goulds-US Pump Model number <input type="checkbox"/> 14JHC HP 125 Volts <input type="checkbox"/> Length of drop pipe 200 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Box A Garden City, Ks. Address <input type="checkbox"/> Signed <input type="checkbox"/> Date 12-20-76 Authorized representative <input type="checkbox"/>		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

ALL TIME
Drill Survey
6-2-76

Location: 23-28-30 661 S. 10th Street
Water Level- 130'

Test #

10	3	Top Soil
12	134	Mixed Colored Clay
14	154	Fine To Med. Sand and Gravel
164	165	Tan Clay with fine sand and gravel
185	190	Fine To Med. Sand and Gravel
200	201	Fine To Med. Sand and Gravel
21	217	Fine To Med. Sand and Gravel
17	292	Sandy Tan Clay
22	324	Fine To Med. Sand and Gravel 20' and 30'
24	349	Fine To Med. Sand and Gravel
262	353	Mixed Colored Clay
263	365	Shale

100' 200'
300'