

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NN 1/4 SW 1/4 SW 1/4	Section number 36	T 28	S 30	R E/W	
2. Distance and direction from nearest town or city: 3 1/2 mi. East 1/2 N Copeland	3. Owner of well: Warren Moore						
Street address of well location if in city: Copeland, Kansas 67837							
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 6 in. Completion date 8/24/78 Well depth 280 ft.			
			7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
5. Type and color of material	From 0	To 150	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
	150	200	9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP 100 PVC 1 Weight 10 lbs./ft. Dia. 5 in. to 200 ft. depth Wall Thickness: inches or Dia. 5 in. to ft. depth gage No. 0.258				
	200	280	10. Screen: Manufacturer's name Peerless Type PVC Dia. 5 in. Slot/gauge 1/16 Length 80 Set between 200 ft. and 280 ft. ft. and ft. Gravel pack? yes Size range of material 1/8				
			11. Static water level: 150 ft. below land surface Date 8/24/78 mo./day/yr.				
			12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.				
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date				
			14. Well head completion: Pitless adapter 14 Inches above grade				
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.				
			16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Waterwell Serv. 142 Business name Box 816 LIBERAL, KS License No. Address Box 816 LIBERAL, KS Signed Chas. L. Moore Date 8/24/78 Authorized representative				
18. Elevation:	19. Remarks:		17. Well to be completed by: Dunham Drilling Co Copeland, Kansas 67837				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							